





# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN  
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

May 04, 2022

AMENDMENT NO.: VI

TO

INVITATION FOR BID NO.: GPA-030-22

FOR

FUSE, CUTOUT

Prospective Bidders are hereby notified of the following:

**CHANGE:**

**REMOVE** Page 3c of 31 and **REPLACE** with 3d of 31 (see attached).

Bid Opening Date is changed **FROM:** 10:00 A.M., Wednesday, May 04, 2022 (CHamoru Standard Time) **TO NOW READ:** 10:00 A.M., Wednesday, May 11, 2022 (CHamoru Standard Time).

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

for JOHN M. BENAVENTE, P.E.  
General Manager 



# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN  
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

April 27, 2022

AMENDMENT NO.: V  
TO  
INVITATION FOR BID NO.: GPA-030-22  
FOR  
FUSE, CUTOUT

Prospective Bidders are hereby notified of the following:

**CHANGE:**

**REMOVE** Page 3b of 31 and **REPLACE** with 3c of 31 (see attached).

Bid Opening Date is changed **FROM:** 11:00 A.M., Wednesday, April 27, 2022  
(CHamoru Standard Time) **TO NOW READ:** 10:00 A.M., Wednesday, May 04, 2022  
(CHamoru Standard Time).

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
for JOHN M. BENAVENTE, P.E.  
General Manager 



# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN  
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

April 25, 2022

AMENDMENT NO.: IV

TO

INVITATION FOR BID NO.: GPA-030-22

FOR

FUSE, CUTOUT

Prospective Bidders are hereby notified of the following response to an inquiry received from Bidder No.: 2 dated March 24, 2022:

**Bidder No.: 2 inquiry dated 03/24/2022:**

**QUESTION:**

1. After reviewing section 3.1.7, and the drawing on page 7 of the Specification it was noted that the specified design has the expendable cap type fuse tube and mounting design. However our S&C's Type XS Fuse Cutouts employ single venting—down and away only—an especially important feature where exhaust must be kept out of other phases in overbuilt circuits. Their nonexpendable fuse-tube cap construction, moreover, eliminates the extra expense of fuse-tube cap replacement. Can GPA accept our Fuse Cutout with nonexpendable fuse-tube cap construction? If yes, then we can prepare a quote.

**ANSWER:**

Based on past orders, we can accept their request.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
for JOHN M. BENAVENTE, P.E.  
General Manager 



# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN  
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

April 19, 2022

AMENDMENT NO.: III  
TO  
INVITATION FOR BID NO.: GPA-030-22  
FOR  
FUSE, CUTOUT

Prospective Bidders are hereby notified of the following:

**CHANGE:**

**REMOVE** Page 3a of 31 and **REPLACE** with 3b of 31 (see attached).

Bid Opening Date is changed **FROM:** 10:00 A.M., Wednesday, April 20, 2022 (CHamoru Standard Time) **TO NOW READ:** 11:00 A.M., Wednesday, April 27, 2022 (CHamoru Standard Time).

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
for JOHN M. BENAVENTE, P.E.  
General Manager 



# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN  
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

April 12, 2022

AMENDMENT NO.: II

TO

INVITATION FOR BID NO.: GPA-030-22

FOR

FUSE, CUTOUT

Prospective Bidders are hereby notified of the following:

**CHANGE:**

**REMOVE** Page 3 of 31 and **REPLACE** with 3a of 31 (see attached).

Bid Opening Date is changed **FROM:** 10:00 A.M., Wednesday, April 13, 2022  
(CHamoru Standard Time) **TO NOW READ:** 10:00 A.M., Wednesday, April 20, 2022  
(CHamoru Standard Time).

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

JOHN M. BENAVENTE, P.E.  
General Manager



# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN  
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

April 05, 2022

AMENDMENT NO.: I

TO

INVITATION FOR BID NO.: GPA-030-22


FOR

FUSE, CUTOUT

Prospective Bidders are hereby notified of the following:

Bid Opening Date is changed **FROM:** 11:00 A.M., Wednesday, April 06, 2022 (CHamoru Standard Time) **TO NOW READ:** 10:00 A.M., Wednesday, April 13, 2022 (CHamoru Standard Time).

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
for JOHN M. BENAVENTE, P.E.  
General Manager  
