# **INVITATION FOR BID**

**ISSUING OFFICE:** 

Guam Power Authority 1st. Floor, Room 101 Procurement Management Materials Supply Gloria B. Nelson Public Service Building 688 Route 15, Mangilao, Guam 96913

Cleline light	<i>S</i> 06/17/2022	
MELINDA R.C. MAFNA General Manager (A)	AS, P.E. DATE	
<u> </u>	06/23/2022 &	
DATE ISSUED:	06/30/2022	BID INVITATION NO.: GPA-046-22
BID FOR:	Pole Mounted Transfo	rmers
SPECIFICATION:	See Attached	
DESTINATION:	GPA Dededo Warehou	use
REQUIRED DELIVERY	DATE: 14 Weeks After	er Approved Drawings by Guam Power Authority
INSTRUCTIONS TO BI	DDERS:	
INDICATE WHETHER:	INDIVIDUAL	PARTNERSHIP CORPORATION
INCORPORATED IN:		<u> </u>
Date: July 13, 2022	and shall be publicly open	e issuing office above no later than (Time) 11:00 A.M. ed. Bid submitted after the time and date specified above shall be and Sealed Bid Solicitation for details.
the respective items listed or expense of the Government	n the schedule provided, unle in opening, tabulating, and e bid remain firm and irrevoca	time specified, the articles and services at the price stated opposite ess otherwise specified by the bidder. In consideration to the evaluating this and other bids, and other considerations, the able within one hundred twenty (120) calendar days from the date e quoted.
NAME AND ADDRESS O	F BIDDER:	SIGNATURE AND TITLE OF PERSON AUTHORIZED TO SIGN THIS BID:
AWARD: CONTRACT NO	O.:GPA-046-22 AMC	DUNT: DATE:
ITEM NO(S). AWARDED:	Item 1.0 (Alternate), It Alternate.	tem 2.0 (Alternate), Item 3.0 (Alternate), and Item 4.0
		CONTRACTING OFFICER:
		for JOHN M. BENAVENTE, P.E. DATE General Manager
NAME AND ADDRESS	OF CONTRACTOR:	SIGNATURE AND TITLE OF PERSON
Benson Guam Ent.		
779 Route 8	_	_ H
Maite, GU 96910		Markating Managar

# **GUAM POWER AUTHORITY**



ATURIDÅT ILEKTRESEDÅT GUÅHAN P.O.BOX 2977 • HAGÅTÑA, GUAM U.S.A. 96932-2977

July 08, 2022

AMENDMENT NO.: I

TO

**INVITATION FOR BID NO.: GPA-046-22** 

FOR

#### POLE MOUNTED TRANSFORMERS

Prospective Bidders are hereby notified of the following response to changes and inquiry received from Bidder No.: 2 dated June 28, 2022:

### **CHANGES:**

1. **REMOVE** Page 3a of 42 and **REPLACE** with 3b of 42 (see attached).

Bid Opening Date is changed *FROM*: 11:00 A.M., Wednesday, July 13, 2022 (CHamoru Standard Time) *TO NOW READ*: 11:00 A.M., Wednesday, July 20, 2022 (CHamoru Standard Time).

- 2. **REMOVE** Page 10 and 11 of 42 and **REPLACE** with 10a and 11a of 42 (see attached).
  - A.1 Single-phase, Insulation Class 15 kV, BIL 95 kV, Primary Voltage 13.8 kV line to line (2 bushing), Secondary voltage 277V without lightning arresters.

## Bidder No.: 2 dated 06/28/2022:

#### QUESTION:

1. Kindly see below the inquiry from our manufacturer. However, item No. 4, Pole mounted TR-single phase, 13.8kV, 277/480V is not correct information. The correct voltage rating of single-phase at LV side is 240/480V, not 277/480V. Please confirm by return soon.

# ANSWER:

Kindly refer to Changes above.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

General Manager for JOHN M. BENAVENTE, P.E.