


INVITATION FOR BID

ISSUING OFFICE:

Guam Power Authority-Procurement Office
1st. Floor, Room 101
Gloria B. Nelson Public Service Building
688 Route 15
Mangilao, Guam 96913

Attn: JOHN M. BENAVENTE, P.E.
General Manager
c/o JAMIE LYNN C. PANGELINAN
Supply Management Administrator


for JOHN M. BENAVENTE, P.E. 7/19/2023 DATE
General Manager

DATE ISSUED: 07/27/2023
08/03/2023 BID INVITATION NO.: GPA-064-23
BID FOR: Pole Mounted Transformers
SPECIFICATION: See Attached
DESTINATION: Guam Power Authority Dededo Warehouse
REQUIRED DELIVERY TIME: See Attached

INSTRUCTIONS TO BIDDERS:

INDICATE WHETHER: INDIVIDUAL PARTNERSHIP CORPORATION
INCORPORATED IN: _____

This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) 9:00 A.M.
Date: August 02, 2023 and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

The undersigned offers and agrees to furnish within the time specified, the articles and services at the price stated opposite the respective items listed on the schedule provided, unless otherwise specified by the bidder. In consideration to the expense of the Government in opening, tabulating, and evaluating this and other bids, and other considerations, the undersigned agrees that this bid remain firm and irrevocable within one hundred twenty (120) calendar days from the date opening to supply any or all of the items which prices are quoted.

NAME AND ADDRESS OF BIDDER: _____ SIGNATURE AND TITLE OF PERSON
AUTHORIZED TO SIGN THIS BID: _____

AWARD: CONTRACT NO.: _____ AMOUNT: _____ DATE: _____

ITEM NO(S). AWARDED: _____

CONTRACTING OFFICER:

JOHN M. BENAVENTE, P.E. DATE
General Manager

NAME AND ADDRESS OF CONTRACTOR: _____ SIGNATURE AND TITLE OF PERSON



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

August 02, 2023

AMENDMENT NO.: I

TO

INVITATION FOR BID NO.: GPA-064-23

FOR

POLE MOUNTED TRANSFORMERS

Prospective Bidders are hereby notified of the following responses and changes to inquiries received from Bidder No. 3 dated July 7, 2023 and Bidder No. 2 dated July 31, 2023

CHANGES:

1. Bid Opening Date is changed **FROM** 09:00 A.M., Tuesday, August 02, 2023 (CHamoru Standard Time) **TO NOW READ** 10:00 A.M., Tuesday, August 16, 2023 (CHamoru Standard Time).
2. **REMOVE** Page 3 of 50 and **REPLACE** with Page 3a of 50 (see attached)

A. Under Invitation for Bid, Instruction to Bidders, Paragraph one has changed **FROM:**

This bid shall be submitted in duplicate and sealed to the issuing office above no later than **(Time) 09:00 A.M.**, **Date: August 02, 2023** and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

TO NOW READ:

* This bid shall be submitted in duplicate and sealed to the issuing office above no later than **(Time) 10:00 A.M.**, **Date: August 16, 2023** and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

- B. Under Date Issued has changed **FROM:**
DATE ISSUED: 07/27/2023
08/03/2023

TO NOW READ:

* DATE ISSUED: 07/27/2023

3. **REMOVE** Page 5, 6, and 7 of 50 and **REPLACE** with Page 5a, 6a, and 7a of 50 (see attached)

- A. Under Delivery Requirements has changed FROM:
AIR FREIGHT – 6 Weeks After Approved Drawings by Guam Power Authority
OCEAN FREIGHT – 10 Weeks After Approve Drawings by Guam Power Authority

TO NOW READ:

*AIR FREIGHT – 12 Weeks After Approved Drawings by Guam Power Authority
*OCEAN FREIGHT – 14 Weeks After Approve Drawings by Guam Power Authority

- B. Under Line item 2.0, A. Specifications A.1 has changed **FROM:**
A.1- Single Phase, Insulation class 15kv, BIL 95kV,

Primary Voltage 13.8kV, Secondary Voltage
120/240 V. without lightning arresters.

TO NOW READ:

* A.1- Single Phase, Insulation class 15kv, BIL 95kV,
Primary Voltage 13.8kV, Secondary Voltage
240/480 V. without lightning arresters.

RESPONSE:

Bidder No.: 3 dated 07/27/2023:

QUESTION:

1. I believe the opening date for GPA-064-23 is too soon. We need to ask for a opening date extension by about 2 weeks.

ANSWER:

Kindly see **CHANGES 1 and 2** above.

Bidder No.: 2 dated 07/31/2023:

QUESTION:

1. We would like to request for an amendment for subject GPA bid to extend the delivery, as follows:
1. Via Air Freight: 12 weeks instead of 6 weeks
 2. Via Ocean freight: 14 weeks instead of 10 weeks

ANSWER:

Kindly see **CHANGES 3** above.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.



for JOHN M. BENAVENTE, P.E.
General Manager

