

### INVITATION FOR BID

**ISSUING OFFICE:**

Guam Power Authority-Procurement Office  
1<sup>st</sup>. Floor, Room 101  
Gloria B. Nelson Public Service Building  
688 Route 15  
Mangilao, Guam 96913

**Attn:** JOHN M. BENAVENTE, P.E.  
General Manager  
c/o JAMIE LYNN C. PANGELINAN  
Supply Management Administrator

  
7/10/2023  
for **JOHN M. BENAVENTE, P.E. DATE**  
**General Manager**

DATE ISSUED: 07/13/2023 BID INVITATION NO.: GPA-055-23  
BID FOR: POLE MOUNTED TRANSFORMERS  
SPECIFICATION: SEE ATTACHED  
DESTINATION: GUAM POWER AUTHORITY, DEDEDO WAREHOUSE  
REQUIRED DELIVERY TIME: 10 Weeks or sooner After Approved Drawings by Guam Power Authority

**INSTRUCTIONS TO BIDDERS:**

INDICATE WHETHER:  INDIVIDUAL  PARTNERSHIP  CORPORATION

INCORPORATED IN: \_\_\_\_\_

This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) 2:00 P.M.,  
Date: July 20, 2023 and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

The undersigned offers and agrees to furnish within the time specified, the articles and services at the price stated opposite the respective items listed on the schedule provided, unless otherwise specified by the bidder. In consideration to the expense of the Government in opening, tabulating, and evaluating this and other bids, and other considerations, the undersigned agrees that this bid remain firm and irrevocable within one hundred twenty (120) calendar days from the date opening to supply any or all of the items which prices are quoted.

NAME AND ADDRESS OF BIDDER:

SIGNATURE AND TITLE OF PERSON  
AUTHORIZED TO SIGN THIS BID:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_

AWARD: CONTRACT NO.: \_\_\_\_\_ AMOUNT: \_\_\_\_\_ DATE: \_\_\_\_\_

ITEM NO(S). AWARDED: \_\_\_\_\_

CONTRACTING OFFICER:

\_\_\_\_\_  
JOHN M. BENAVENTE, P.E. DATE  
General Manager

NAME AND ADDRESS OF CONTRACTOR:

SIGNATURE AND TITLE OF PERSON

\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_



# GUAM POWER AUTHORITY

ATURIDÂT ILEKTRESEDÂT GUÂHAN  
P.O.BOX 2977 • HAGÂTÑA, GUAM U.S.A. 96932-2977

July 19, 2023

AMENDMENT NO.: I

TO

INVITATION FOR BID NO.: GPA-055-23

FOR

POLE MOUNTED TRANSFORMERS

Prospective Bidders are hereby notified of the following changes and responses to inquiries received from Bidder No. 1 dated July 17, 2023, Bidder No. 3 dated July 18, 2023 and Bidder No. 2 dated July 18, 2023:

**CHANGES:**

1. Bid Opening Date is changed *FROM* 2:00 P.M., Thursday, July 20, 2023 (CHamoru Standard Time) *TO NOW READ* 2:00 P.M., Friday, July 28, 2023 (CHamoru Standard Time).
2. *REMOVE* Page 3 of 54 and *REPLACE* with Page 3a of 54 (see attached):
  - a. Under INVITATION FOR BID, INSTRUCTION TO BIDDERS, Paragraph one has changed

***FROM:***

This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) 2:00 P.M., (Guam CHamoru Standard Time; ChST), Date: July 20, 2023 and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

**\* *TO NOW READ:***

This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) 2:00 P.M., (Guam CHamoru Standard Time; ChST), Date: July 28, 2023 and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

b. Under INVITATION FOR BID, REQUIRED DELIVERY TIME is changed

**FROM:**

10 Weeks or sooner After Approved Drawings by Guam Power Authority

**TO NOW READ:**

\* 15 Weeks or sooner After Approved Drawings by Guam Power Authority

3. REMOVE Pages 5, 7, 9 and 11 of 54 and REPLACE with Pages 5a, 7a, 9a and 11a of 54 (see attached).

Under DESCRIPTION, DELIVERY REQUIREMENT is changed

**FROM:**

10 Weeks or sooner After Approved Drawings by Guam Power Authority

**TO NOW READ:**

\* 15 Weeks or sooner After Approved Drawings by Guam Power Authority

**Bidder No.: 1 dated 07/17/2023:**

**QUESTION:**

1. We would like to request for an amendment for subject bid to give us ample time to submit our competitive bid prices.
  - 1) Extension of bid opening date for 8 days or July 28, 2023.
  - 2) Required delivery time to 20 weeks instead of 10 weeks only.

Your approval to our above request is greatly appreciated.

**ANSWER:**

Kindly refer to No. 1, 2 and 3 of *CHANGES* above.

**Bidder No.: 3 dated 07/18/2023:**

**QUESTION:**

1. May we kindly request for an extension to submit our proposal from July 20, 2023 to July 25, 2023, the same time.  
This will give us enough time to prepare our proposal.

**ANSWER:**

Kindly refer to No. 1 and 2 a. of *CHANGES* above.

**Bidder No.: 2 dated 07/18/2023:**

**QUESTION:**

1. We're going to have to ask for an opening date extension by one more week.

Our suppliers for these items need a bit more time to put together a proposal. Your kind consideration is much appreciated.

**ANSWER:**

Kindly refer to No. 1 and 2 a. of *CHANGES* above.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.



for JOHN M. BENAVENTE, P.E.  
General Manager



INVITATION FOR BID

ISSUING OFFICE:

Guam Power Authority-Procurement Office
1st. Floor, Room 101
Gloria B. Nelson Public Service Building
688 Route 15
Mangilao, Guam 96913

Attn: JOHN M. BENAVENTE, P.E.
General Manager
c/o JAMIE LYNN C. PANGELINAN
Supply Management Administrator

Handwritten signature and date 7/24/2023
for JOHN M. BENAVENTE, P.E. DATE
General Manager

DATE ISSUED: 07/13/2023 BID INVITATION NO.: GPA-055-23

BID FOR: POLE MOUNTED TRANSFORMERS

SPECIFICATION: SEE ATTACHED

DESTINATION: GUAM POWER AUTHORITY, DEDEDO WAREHOUSE

\* REQUIRED DELIVERY TIME: 15 Weeks or sooner After Approved Drawings by Guam Power Authority

INSTRUCTIONS TO BIDDERS:

INDICATE WHETHER: INDIVIDUAL PARTNERSHIP CORPORATION

INCORPORATED IN:

\* This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) 2:00 P.M. Date: July 28, 2023 and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

The undersigned offers and agrees to furnish within the time specified, the articles and services at the price stated opposite the respective items listed on the schedule provided, unless otherwise specified by the bidder. In consideration to the expense of the Government in opening, tabulating, and evaluating this and other bids, and other considerations, the undersigned agrees that this bid remain firm and irrevocable within one hundred twenty (120) calendar days from the date opening to supply any or all of the items which prices are quoted.

NAME AND ADDRESS OF BIDDER:

SIGNATURE AND TITLE OF PERSON AUTHORIZED TO SIGN THIS BID:

AWARD: CONTRACT NO.: AMOUNT: DATE:

ITEM NO(S). AWARDED:

CONTRACTING OFFICER:

JOHN M. BENAVENTE, P.E. DATE
General Manager

NAME AND ADDRESS OF CONTRACTOR:

SIGNATURE AND TITLE OF PERSON

INVITATION FOR NO.: GPA-055-23  
Requisition No.: 37727

NO.	DESCRIPTION	QTY.	U/I	UNIT PRICE:	TOTAL PRICE:
-----	-------------	------	-----	-------------	--------------

- E.2 Information for shop drawings shall include:
- a. Mounting Dimensions
  - b. Location of Equipment, Devices and Terminals
  - c. Weights
  - d. Number of Gallons of Oil
  - e. Nameplate Data
  - f. Connection Diagrams
  - g. Guaranteed Total Loss at 100% Voltage and Load
  - h. Guaranteed No-Load Loss at Rated Voltage

**COMPLY:**

**NOT COMPLY:**

_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

**\*\* APPROVED EQUAL TO OR BETTER \*\***

**NOTE:**  
Notwithstanding the fact that this contract was written  
By one (1) party, it will be construed that it was written  
By two (2) parties.

All deviations shall be identified  
Referencing the Section and Sub-  
Section(s) from the attached GPA  
Specification

REMARKS / DEVIATIONS:

**\*DELIVERY REQUIREMENT:**  
15 Weeks or sooner After Approved Drawings by Guam Power Authority

_____
_____
_____
_____

**COMPLY:**

**NOT COMPLY:**

Reasonable delivery extension requests for this specific  
bid will be duly considered with the supporting manufacturer  
documentation however, such requests are not guaranteed  
approval due to critical and urgent need of the materials  
to support the Guam Power Authority's needs.

_____	_____
-------	-------

TO BE COMPLETED BY BIDDER:

MANUFACTURED/BRAND NAME: \_\_\_\_\_

CAT. NO. / MODEL NO.: \_\_\_\_\_

PLACE OF ORIGIN: \_\_\_\_\_

EXPORT ABROAD: \_\_\_\_\_

TIME OF DELIVERY AFTER RECEIPT OF  
PURCHASE ORDER: \_\_\_\_\_

Specifications Generated/Reviewed by:

*Angelapuree Balajadia* 07/19/2023  
ANGELA BALAJADIA Date  
Inventory Management Officer

Specifications Reviewed by:

*Louis C. Camacho P.E.* 7/19/2023  
LOUIS C. CAMACHO, P.E. Date  
Engineering Supervisor

Specifications Approved by:

*[Signature]* 7/24/2023  
BEATRICE LIMITIACO Date  
Assistant General Manager of Administration

INVITATION FOR NO.: GPA-055-23  
Requisition No.: 37727

NO.	DESCRIPTION	QTY.	U/I	UNIT PRICE:	TOTAL PRICE:
-----	-------------	------	-----	-------------	--------------

- E.2 Information for shop drawings shall include:
- a. Mounting Dimensions
  - b. Location of Equipment, Devices and Terminals
  - c. Weights
  - d. Number of Gallons of Oil
  - e. Nameplate Data
  - f. Connection Diagrams
  - g. Guaranteed Total Loss at 100% Voltage and Load
  - h. Guaranteed No-Load Loss at Rated Voltage

**COMPLY:**

**NOT COMPLY:**

_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

**\*\* APPROVED EQUAL TO OR BETTER \*\***

**NOTE:**  
Notwithstanding the fact that this contract was written  
By one (1) party, it will be construed that it was written  
By two (2) parties.

All deviations shall be identified  
Referencing the Section and Sub-  
Section(s) from the attached GPA  
Specification

REMARKS / DEVIATIONS:

_____
_____
_____

**\*DELIVERY REQUIREMENT:**

15 Weeks or Sooner After Approved Drawings by Guam Power Authority

Reasonable delivery extension requests for this specific  
bid will be duly considered with the supporting manufacturer  
documentation however, such requests are not guaranteed  
approval due to critical and urgent need of the materials  
to support the Guam Power Authority's needs.

**COMPLY:**

**NOT COMPLY:**

_____	_____
-------	-------

**TO BE COMPLETED BY BIDDER:**

MANUFACTURED/BRAND NAME: \_\_\_\_\_

CAT. NO. / MODEL NO.: \_\_\_\_\_

PLACE OF ORIGIN: \_\_\_\_\_

EXPORT ABROAD: \_\_\_\_\_

TIME OF DELIVERY AFTER RECEIPT OF  
PURCHASE ORDER: \_\_\_\_\_

Specifications Generated/Reviewed by:

*Angela Balajadia* 07/19/2023

ANGELA BALAJADIA Date

Inventory Management Officer

Specifications Reviewed by:

*Louis C. Camacho P.E.* 7/19/2023

LOUIS C. CAMACHO, P.E. Date

Engineering Supervisor

Specifications Approved by:

*[Signature]* 7/23/2023

BEATRICE P. LIMTIACO Date

Assistant General Manager of Administration

INVITATION FOR NO.: GPA-055-23  
Requisition No.: 37727

NO.	DESCRIPTION	QTY.	U/I	UNIT PRICE:	TOTAL PRICE:
				<b>COMPLY:</b>	<b>NOT COMPLY:</b>
	E.2 Information for shop drawings shall include:			_____	_____
	a. Mounting Dimensions			_____	_____
	b. Location of Equipment, Devices and Terminals			_____	_____
	c. Weights			_____	_____
	d. Number of Gallons of Oil			_____	_____
	e. Nameplate Data			_____	_____
	f. Connection Diagrams			_____	_____
	g. Guaranteed Total Loss at 100% Voltage and Load			_____	_____
	h. Guaranteed No-Load Loss at Rated Voltage			_____	_____

**\*\* APPROVED EQUAL TO OR BETTER \*\***

**NOTE:**

Notwithstanding the fact that this contract was written  
By one (1) party, it will be construed that it was written  
By two (2) parties.

All deviations shall be identified  
Referencing the Section and Sub-  
Section(s) from the attached GPA  
Specification

REMARKS / DEVIATIONS:

**\*DELIVERY REQUIREMENT:**

15 Weeks or Sooner After Approved Drawings by Guam Power Authority

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Reasonable delivery extension requests for this specific  
bid will be duly considered with the supporting manufacturer  
documentation however, such requests are not guaranteed  
approval due to critical and urgent need of the materials  
to support the Guam Power Authority's needs.

<b>COMPLY:</b>	<b>NOT COMPLY:</b>
_____	_____

**TO BE COMPLETED BY BIDDER:**

MANUFACTURED/BRAND NAME: \_\_\_\_\_

CAT. NO. / MODEL NO.: \_\_\_\_\_

PLACE OF ORIGIN: \_\_\_\_\_

EXPORT ABROAD: \_\_\_\_\_

TIME OF DELIVERY AFTER RECEIPT OF  
PURCHASE ORDER: \_\_\_\_\_

**Specifications Generated/Reviewed by:**

*Angela Balajadia* 07/19/2023  
ANGELA BALAJADIA Date  
Inventory Management Officer

**Specifications Reviewed by:**

*Louis C. Camacho P.E.* 7/19/2023  
LOUIS C. CAMACHO, P.E. Date  
Engineering Supervisor

**Specifications Approved by:**

*[Signature]* 7/24/2023  
BEATRICE P. LIMTIACO Date  
Assistant General Manager of Administration



INVITATION FOR NO.: GPA-055-23  
Requisition No.: 37727

NO.	DESCRIPTION	QTY.	U/I	UNIT PRICE:	TOTAL PRICE:
-----	-------------	------	-----	-------------	--------------

- E.2 Information for shop drawings shall include:
- a. Mounting Dimensions
  - b. Location of Equipment, Devices and Terminals
  - c. Weights
  - d. Number of Gallons of Oil
  - e. Nameplate Data
  - f. Connection Diagrams
  - g. Guaranteed Total Loss at 100% Voltage and Load
  - h. Guaranteed No-Load Loss at Rated Voltage

**COMPLY:**

**NOT COMPLY:**

_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

**\*\* APPROVED EQUAL TO OR BETTER \*\***

**NOTE:**  
Notwithstanding the fact that this contract was written  
By one (1) party, it will be construed that it was written  
By two (2) parties.

All deviations shall be identified  
Referencing the Section and Sub-  
Section(s) from the attached GPA  
Specification

REMARKS / DEVIATIONS:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**\* DELIVERY REQUIREMENT:**

15 Weeks or Sooner After Approved Drawings by Guam Power Authority

Reasonable delivery extension requests for this specific  
bid will be duly considered with the supporting manufacturer  
documentation however, such requests are not guaranteed  
approval due to critical and urgent need of the materials  
to support the Guam Power Authority's needs.

**COMPLY:**

**NOT COMPLY:**

\_\_\_\_\_

**TO BE COMPLETED BY BIDDER:**

MANUFACTURED/BRAND NAME: \_\_\_\_\_

CAT. NO. / MODEL NO.: \_\_\_\_\_

PLACE OF ORIGIN: \_\_\_\_\_

EXPORT ABROAD: \_\_\_\_\_

TIME OF DELIVERY AFTER RECEIPT OF  
PURCHASE ORDER: \_\_\_\_\_

Specifications Generated/Reviewed by:

*Angela Balajadia* 07/19/2023

ANGELA BALAJADIA Date  
Inventory Management Officer

Specifications Reviewed by:

*Louis C. Camacho P.E.* 7/19/2023

LOUIS C. CAMACHO, P.E. Date  
Engineering Supervisor

Specifications Approved by:

*[Signature]* 7/23/2023

BEATRICE P. LIMTIACO Date  
Assistant General Manager of Administration