



GUAM POWER  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 1 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

## **GUAM POWER AUTHORITY**

Post Office Box 2977  
Hagåtña, Guam 96932

### **TRANSMISSION AND DISTRIBUTION SPECIFICATION**

Specification No. E-034

FOR

**34.5 KV/13.8 KV  
18/24/30 MVA  
POWER TRANSFORMER  
OUTDOOR TYPE**

EFFECTIVE DATE: **06-04-24**

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 2 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

**34.5 KV/13.8 KV  
18/24/30 MVA  
POWER TRANSFORMER  
OUTDOOR TYPE**

	Table of Contents	
1.0	Scope	3
2.0	Service Conditions and Operation	3
3.0	Conformance to Specification Requirements	3
4.0	Data to be Provided	5
5.0	Ratings	12
6.0	Construction	14
7.0	Tank	24
8.0	Transformer Oil	25
9.0	Transformer Cooling	25
10.0	Testing	27
11.0	Loss Evaluation	29
12.0	Oil Preservation System	31
13.0	Finishing Requirements	31
14.0	Shipping Requirements	31
15.0	Statement of Compliance	32
16.0	Warranty	32

EFFECTIVE DATE: 06-04-24

ISSUED: 

APPROVED: 



GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 3 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

### 1.0 SCOPE:

This specification covers Guam Power Authority's requirement for three-phase power transformer and accessories.

### 2.0 SERVICE CONDITIONS AND OPERATION:

2.1 The three-phase power transformer and its accessories are intended for use in an average ambient temperature of 21-32 deg. C (70-90 deg. F) with corrosive, salt air environment, sustained wind strengths of 170 MPH, and subject to IBC seismic zone 4 conditions.

2.2 Transformer will be used for distribution step-down operation.

### 3.0 CONFORMANCE TO SPECIFICATION REQUIREMENTS:

Transformer shall meet the requirements of the following standards and specifications, including latest revisions with respect to material, design and tests.

#### 3.1 Applicable Standards

AMERICAN NATIONAL STANDARDS INSTITUTE, INC. (ANSI)

C57.12.00	IEEE Standard for General Requirements for Liquid-Immersed Distribution, Power, and Regulating Transformers
C57.12.80	IEEE Standard Terminology for Power and Distribution Transformers
C57.12.90	IEEE Standard Test Code for Liquid-Immersed Distribution, Power, and Regulating Transformers
C57.12.70	IEEE Standard for Terminal Markings and Connections for Distribution and Power Transformers
C57.19.00	IEEE Standard General Requirements and Test Procedure for Power Apparatus Bushings
C57.19.01	IEEE Standard Performance Characteristics and Dimensions for Outdoor Apparatus Bushings

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 4 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

### NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

TR 1	Transformers, Step Voltage Regulators and Reactors
------	--

### AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

D92-78	Standard Test Method for Flash and Fire Points by Cleveland Open Cup Tester
D877-84	Standard Test Method for Dielectric Breakdown voltage of Insulating Liquids Using Disk Electrodes

### NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

70	National Electrical Code
70B	Standard for Electrical Equipment Maintenance

### UNDERWRITER'S LABORATORIES, INC. (UL)

UL 467	UL Standard for Safety Grounding and Bonding Equipment
--------	--

### INTERNATIONAL ELECTRICAL TESTING ASSOCIATION (IETA)

ANSI/NETA ATS -2021	Standard for Acceptance Testing Specification for Electrical Power Equipment and Systems
---------------------	--

## 3.2 Deviations and Non - Conformance Requirements

3.2.1 Deviations from this specification or changes in the material or design after the purchase order has been placed must be approved by the GPA Engineering Department and acknowledged by a Purchase Order Amendment issued by Guam Power Authority.

3.2.2 Units received with deviations or non - conformance that are not acknowledged as specified in Section 3.2.1, are subject to rejection. The Supplier of rejected units is responsible for any corrective action including but not limited to materials, labor and transportation necessary to dispose of, or make the units conform to this specification.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:





GUAM POWER  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 5 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

3.2.3 Notification of defects discovered before or after installation that are believed to be inherent to manufacturing problems or workmanship shall be made and forwarded to the Supplier. The description of the item, documentation of the problem and the described information, disposition and/or follow-up (as appropriate) that Guam Power Authority expects from the Supplier will be specified. The Supplier's response shall be made within thirty (30) days unless an extension is acknowledged and approved in writing by the GPA Manager of Engineering.

**4.0 DATA TO BE PROVIDED:**

4.1 The Bidder shall provide with his bid the following data:

1. Transformer

- a. Manufacturer
- b. Type, Core
- c. Windings, Two-winding
- d. Service Area, Outdoor
- e. Factory Technician Representative on Site
- f. Warranty, 1-Year
- g. Quantity

---

---

---

---

---

---

---

2. Delivery Date

- a. 8 months ARO or the earliest date

---

3. Rating

- a. Rated Output Capacity, 18/24/30 MVA
- b. Number of Phase, 3
- c. Rated Frequency, 60 Hz
- d. HV rating and connections, 34.5 kV/Delta
- e. LV rating and connections, 13.8 kV/Grounded Wye
- f. Vector Group, Dyn1
- g. HV Tap Steps, 5  
HV Tap Voltage, 34.5 kV +/- 2 x 2.5%
- h. LV Tap Steps, 32  
LV Tap Voltage, 13.8 kV +/- 16 x 0.625%
- i. Cooling Class

---

---

---

---

---

---

---

---

---

---

4. High Voltage (HV) Bushings

- a. Manufacturer/ Country
- b. Model/ Part No.

---

---

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 6 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

- c. Voltage Class, 35 kV
- d. Minimum BIL, 200 kV
- e. Minimum Voltage Creepage, 35 Inches

5. Low Voltage (LV) Bushings

- a. Manufacturer/ Country
- b. Model/ Part No.
- c. Voltage Class, 15 kV
- d. Minimum BIL, 110 kV
- e. Minimum Voltage Creepage, 15 Inches

6. Low Voltage Neutral (LVN) Bushing

- a. Manufacturer/ Country
- b. Model/ Part No.
- c. Voltage Class, 15 kV
- d. Minimum BIL, 110 kV
- e. Minimum Voltage Creepage, 15 Inches

7. High Voltage (HV) Bushing Current Transformers

- a. Manufacturer/ Country
- b. Model/ Part No.
- c. MRCT, 1200/5
- d. Class, C800
- e. Burden, 100 VA

8. Low Voltage (LV) Bushing Current Transformers

- a. Manufacturer/ Country
- b. Model/ Part No.
- c. MRCT, 2000/5
- d. Class, C800
- e. Burden, 100 VA

9. Low Voltage (LVN) Bushing Current Transformer

- a. Manufacturer/ Country
- b. Model/ Part No.
- c. MRCT, 600/5
- d. Class, C800
- e. Burden, 100 VA

10. Spare Bushings

- a. HV Bushings, 2 each
- b. LV Bushings, 2 each
- c. LVN Bushing, 1 each

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 7 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

**11. Guaranteed Efficiency at 100% Power Factor**

- a. At 1-1/4 load (125%)
- b. At full load (100%)
- c. At 3/4 load (75%)
- d. At 1/2 load (50%)
- e. At 1/4 load (25%)

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**12. Guaranteed Regulation at 100% Load**

- a. At 100% power factor
- b. At 80% power factor

\_\_\_\_\_  
\_\_\_\_\_

**13. Guaranteed Loss**

- a. Total loss at 100% voltage, kW
- b. Load loss ( $P_k$ ) at rated voltage, kW
- c. No-load loss ( $P_o$ ) at rated voltage, kW
- d. No-load loss at 110 % voltage, kW
- e. Maximum auxiliary power loss, kW

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**14. Guaranteed Exciting Current**

- a. At 100% voltage, Amps
- b. At 110 % voltage, Amps

\_\_\_\_\_  
\_\_\_\_\_

**15. Guaranteed percent impedance, 7.5%**

\_\_\_\_\_

**16. Calculated zero-sequence percent impedance, %**

\_\_\_\_\_

**17. Guaranteed maximum average audible sound level for each stage of cooling**

- a. Self-Cooled, dB
- b. 1<sup>st</sup> Stage, dB
- c. 2<sup>nd</sup> Stage, dB

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**18. Forced Cooling**

- a. Cooling power requirements, kW
- b. Auxiliary power, Volts

\_\_\_\_\_  
\_\_\_\_\_

**19. Total Auxiliary Load with cooling, LTC, and cabinet space heaters**

- a. Power Requirements ( $P_{co}$ ) at No-Load Operation, kW
- b. Power Requirements ( $P_{cs}$ ) at Rated Power Operation, kW
- c. Auxiliary power, volts

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**20. Type of Oil Preservation System**

\_\_\_\_\_

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 8 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

21. Method of mounting radiators

- a. Removable or Integral with the tank

\_\_\_\_\_

22. Shipping data

- a. Shipping weight, Lbs.  
b. Shipping dimension (LxWxH), Inches  
c. Oil or gas filled

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

23. Transformer Overall Dimension (LxWxH), Inches

\_\_\_\_\_

24. Type of transformer winding material used for all windings

- a. HV windings, COPPER  
b. LV windings, COPPER

\_\_\_\_\_

\_\_\_\_\_

25. No Voltage Tap Changer

- a. Manufacturer/ Country  
b. Model/ Part No.  
c. Current rating, Amps

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

26. Load Tap Changer

- a. Manufacturer/ Country, ABB  
b. Model/ Part No.  
c. Current rating, Amps

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

27. Automatic Voltage Regulator (AVR)

- a. Manufacturer/ Country, Beckwith Electric/ USA  
b. Model/ Part No., M-2001D

\_\_\_\_\_

\_\_\_\_\_

28. Dissolve Gas Analysis (DGA) or Fault Gas and Moisture Monitor

- a. Manufacturer/ Country, GE USA  
b. Model/ Part No., Hydran M2

\_\_\_\_\_

\_\_\_\_\_

29. Spare Hydran M2 Sensor 0-2000 ppm

- a. Part No.16270, 2 each

\_\_\_\_\_

30. LTC Filtration System

- a. Manufacturer/ Country, Oil Filtration Systems/ USA  
b. Model/ Part No., LTCFS-6-S514D/2-120-N4-B

\_\_\_\_\_

\_\_\_\_\_

31. HV Surge Arresters

- a. Manufacturer/ Country  
b. Voltage rating (duty cycle), rms kV

\_\_\_\_\_

\_\_\_\_\_

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:





GUAM POWER  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 9 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

- c. Max. continuous operating voltage, rms kV
- d. One second TOV capability, rms kV
- e. Creepage distance, inches
- f. Total weight of each unit, lbs.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**32. LV Surge Arresters**

- a. Manufacturer/ Country
- b. Voltage rating (duty cycle), rms kV
- c. Max. continuous operating voltage, rms kV
- d. One second TOV capability, rms kV
- e. Creepage distance, inches
- f. Total weight of each unit, lbs.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**33. Oil**

- a. Manufacturer/ Country
- b. Product, INHIBITED
- c. Type, ASTM D3487 Type II
- d. Amount required, Main tank, gals  
Conservator tank, gal.
- e. Total weight, Main tank, lbs.  
Conservator tank, lbs.
- f. Method of delivery

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**34. Target Type Fault Indicator**

- a. Manufacturer/ Country, Fuji Electric/ Japan
- b. Model/Part No., TK Series/ TKL 200-DC12-B

\_\_\_\_\_  
\_\_\_\_\_

**35. Anchor Bolts, 1" dia. x 16" L**

\_\_\_\_\_

**36. Space Heaters at HV and LV Terminal Cabinets**

\_\_\_\_\_

**37. Attach list of recommended spare parts with quantities.**

**38. Attach list of special tools.**

**39. Bidder shall include in his bid proposal the cost for three (3) Guam Power Authority's representatives to witness factory testing.**

**40. In the event that the factory witness testing is cancelled or does not occur, the bid costs for the testing shall be deducted from the overall cost. The manufacturer shall provide factory test results, videos, and pictures of the testing.**

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 10 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

**4.2** An outline drawing shall be provided with each bid quotation. This drawing shall include the following information:

- a. Projected floor space of the transformer, including radiators and expansion tanks.
- b. Height of transformer from floor level to top of high-voltage bushing.
- c. Height of transformer from floor level to top of low-voltage bushing.
- d. Height of transformer from floor level to top of tank, and to the highest non-removable part.
- e. Weight of core and windings.
- f. Weight of tank and radiators.
- g. Number of gallons of oil and total weight of the oil.
- h. Total weight of the assembled transformer including oil.
- i. Power requirements for all control and auxiliary equipment.

**4.3** Within ten (10) weeks after award of contract, the successful bidder shall provide the following drawings for Guam Power Authority approval.

**4.3.1** Nameplate drawing including all current transformer ratios.

**4.3.2** Outline drawing including the following:

- a. Accessories and location
- b. Weights with and without oil
- c. Shipping center of gravity-shown on two views.
- d. Installed center of gravity-shown on two views.
- e. Anchoring requirements.

**4.3.3** Base drawing including anchor bolt locations, completely detailed and dimension from equipment center lines:

- a. Bushing outlines including size of stud, thread size and thread length.
- b. Surge arrester outlines.
- c. Location of radiators.
- d. Location of conservator.
- e. Control elementary and wiring diagrams.
- f. LTC control elementary and wiring diagrams.
- g. Current transformer elementary and wiring diagrams.
- h. Current transformer ratio correction factor and secondary excitation curves.

The Supplier shall supply three (3) sets of prints of the above requirements. In addition, a list indicating the drawing number and title of each drawing shall be provided.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 11 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

### 4.4 Drawings Approval

- 4.4.1 Guam Power Authority shall be allowed three (3) weeks to review and approve drawings provided in Section 4.3 without affecting the shipping date.
- 4.4.2 Drawings returned to the Supplier as approved shall be considered authorization to proceed with the work. The approval of Guam Power Authority shall in no way abrogate with the requirements of this specification.

### 4.5 Certified Reproducible

- 4.5.1 At least three (3) weeks prior to shipment of the equipment the Supplier shall furnish Guam Power Authority an AutoCAD file (AutoCAD version to be determined by GPA), a certified reproducible hard copy and soft file in pdf format for each transformer. Under no circumstances will "Typical Drawings" be accepted. This includes both schematic and wiring diagrams.
- 4.5.2 The Supplier shall provide three (3) Final certified reproducible hardcopies (11" x 17" Ledger Paper, ANSI B. A3) and one (1) soft file in pdf format. The following information shall be shown on each drawing submitted:
  - a. Guam Power Authority Purchase Order
  - b. Supplier's Name
  - c. Description of Drawing

### 4.6 Installation, Operation and Maintenance Manuals

- 4.6.1 The Supplier shall provide Guam Power Authority with three (3) sets of hardcopies and one (1) soft file in pdf format of full Installation, Operating and Maintenance Manuals for each unit, at least three (3) weeks prior to delivery.
- 4.6.2 One (1) additional Installation, Operation and Maintenance Manual shall be placed with each unit within the transformer control or marshalling cabinet.
- 4.6.3 Each set of manuals shall include the following:
  - a. Both schematic and wiring drawings. No typical drawings are acceptable.
  - b. List of parts that were shipped loose from the transformer and to be installed in the field.
  - c. A replacement parts list that includes part number identification.
  - d. A list of recommended spare parts and complete packing lists of accessory items.
  - e. Instruction manuals covering step-by-step installation and assembly with illustrative drawings. Each separate part shall be marked with or

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 12 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

- identification system to aid in erection.
- f. Manual recommending proper storage procedures.
- g. Operating and "troubleshooting" manual for the transformer.
- h. List of all special tools needed for installation and maintenance.

### 5.0 RATINGS:

#### 5.1 Description

Transformer shall be a three-phase, oil-immersed, outdoor type unit for use on a 60 hertz effectively grounded system. Transformer windings (primary and secondary) shall be made of COPPER.

#### 5.2 Operations and Environment

The transformer is to be used for step-down operation, in a salt air environment near sea level with ambient temperatures ranging between 21-32 deg. C (70-90 deg. F).

#### 5.3 KVA Rating/Temperature Rise

The transformer shall have the following ratings:

Self-Cooled OA	18 MVA
1 <sup>st</sup> Stage Fans FA	24 MVA
2 <sup>nd</sup> Stage Fans FA	30 MVA

The average winding temperature use will not exceed 65-degree C (measured by resistance method) when operated at the OA/FA/FA rating.

#### 5.4 Voltage Ratings and Phase Displacement

- 5.4.1 The primary winding (high voltage) shall be rated 34,500 volts, delta connected.
- 5.4.2 The secondary winding (low voltage) shall be rated 13,800 Y/ 7970 volts, grounded wye connected.
- 5.4.3 The phase displacement between the 34,500 volt and the 13,800 volt winding shall be 30 electrical degrees with the low voltage lagging the high voltage in a counter-clockwise phase rotation. The vector group of the transformer shall be Dyn1.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:





GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 13 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

### 5.5 Basic Insulation Levels (BIL)

The BIL ratings shall be as tabulated:

High Voltage Winding	200 KV
Low Voltage Winding	110 KV
Low Voltage Neutral Winding	110 KV

### 5.6 Impedance

The percent impedance voltage for the high to low voltage windings (H-X) shall be 7.5 percent on the unit's OA rating; impedance shall have tolerances as specified in ANSI Standard C5.12.00.

### 5.7 Sound Level

5.7.1 The average sound level of transformer shall be of a standard sound level or reduced sound level. Standard sound levels shall not exceed 71/72/73 db based on the transformer rating in accordance with NEMA TR-1 Standards. Reduced sound level transformers shall be 12dB below the standard and shall not exceed the levels for 59/60/61dB for OA/FA/FA, OA/FA/FOA or OA/FOA/FOA ratings.

5.7.2 The transformer sound level shall be reduced by reducing the flux density of the core.

5.7.3 The Supplier shall state in his quotation the price difference between a standard sound level and a reduced sound level transformer.

### 5.8 Surge Arresters

5.8.1 Station class metal oxide surge arresters shall be provided.

5.8.2 The Maximum Continuous Operating Voltage rated 27 kV rms shall be 22 kV MCOV for the transformer HV terminals. High voltage arresters shall be cover mounted, ABB type or equal.

5.8.3 The Maximum Continuous Operating Voltage rated 10 kV rms shall be 8.4 kV MCOV for the transformer LV terminals. Low voltage arresters shall be cover mounted, ABB type or equal.

EFFECTIVE DATE: 06 04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 14 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

### 6.0 CONSTRUCTION:

#### 6.1 Bushings

- 6.1.1. High voltage bushings shall be of the paper and oil "capacitor" TYPE, ANSI Standard Inter-changeable, with visible oil level gauge at the top of each bushing. Each bushing shall be provided with a power factor test tap. Bushing color shall be ANSI 70 light gray. Threaded stud for connection of bushing to cable or straps shall be silver-plated.
- 6.1.2. Low voltage phase and all neutral bushings shall be of the dry-type, one- piece porcelain body, or acceptable condenser type. Threaded stud for connection of bushing to cable or straps shall be silver-plated. The bushing color shall be ANSI 70 light gray.
- 6.1.3. All bushings minimum creepage distance is 1 inch/ kV. Bushings provided with the transformer shall be in accordance with the following:

BUSHING	VOLTAGE CLASS KV	MINIMUM BIL KV	MINIMUM VOLTAGE CREEPAGE IN	LOCATION
HV Phase	35	200	35	Cover Mtd.
LV Phase	15	110	15	Cover Mtd.
LV Neutral	15	110	15	Cover Mtd.

- 6.1.4. Two each spare bushing shall be provided for both high and low voltage bushings. And one each spare bushing shall be provided for low voltage neutral bushing.
- 6.1.5. HV and LV terminal cabinets used for termination of underground power cables to the bushings shall be provided with space heater and cable support. Bushing terminals shall be at least 60 inches from the cable entry at the bottom of the cabinet to avoid stressing the cables when terminated.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 15 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

### 6.2 Bushing Current Transformers

- 6.2.1. Standard multi-ratio current transformers for Authority's use are required as follows:

Each HV Phase Bushing	Two (2) 1200/5 MRCT accuracy C800.
Each LV Phase Bushing	Two (2) 2000/5 MRCT accuracy C800.
LV Neutral Bushing	One (1) 600/5 MRCT accuracy C800.

- 6.2.2. All secondary tap leads (total of five for each CT) shall be brought out of the top or side wall of the transformer through a gas and oil tight compartment and wired to identified circuit shorting terminal blocks in the transformer control cabinet. All connections between CT's and GPA connection points shall be bolted or crimped. No soldered, split or disconnecting lugs shall be used.
- 6.2.3. All CT circuits shall be terminated into an eight-pole test switch.
- 6.2.4. The manufacturer shall provide accuracy curves for the current transformers furnished.
- 6.2.5. Bushing CT Nameplates shall be provided showing connection and ratio for each tap of each current transformer. These nameplates shall be mechanically fastened and located adjacent to GPA's connection terminals.

### 6.3 Tap Changers

#### 6.3.1 High Voltage De-Energized Manual Taps

Externally operated, full KVA capacity, fixed taps shall be provided to regulate the high voltage + 2 1/2 % and + 5 % from the nominal voltage. The high voltage de-energized tap changer shall be operable by a wheel, crank, or lever accessible by an operator standing at ground level. The operating device shall have provisions for padlocking. Each tap position and associated voltage for that tap shall be clearly identified on a tap position nameplate mounted on the transformer wall directly adjacent to the operating device. The nameplate shall state "For De-Energized Operation Only".

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

PREPARED BY THE  
ENGINEERING DEPARTMENT

## SPECIFICATION No. E-034

PAGE 16 of 32

JUNE 4, 2024

REV. 6

### 6.3.2 Low Voltage Automatic Load Tap Changer

1. Manufacturer: ABB
2. Location: Low voltage winding
3. Regulating Range: 10 percent above to 10 percent below rated voltage in 16 steps of 5/8 percent in each direction.
4. Rating: Delivered full kVA capacity at all LTC positions and at all combinations of LTC positions.
5. Tap Selector Switch and Mechanism:
  - a. Mount in oil-filled compartment separate from main transformer tank.
  - b. Maintain physical isolation so it is not necessary to drain oil or break seal of main transformer tank when servicing LTC.
  - c. Tank Accessories:
    - i. Hinged maintenance door with oil-resistant gasket.
    - ii. Drain, filter, and separating valves.
    - iii. Magnetic level indicator with low level 125 vdc alarm contacts.
    - iv. Breather.
    - v. Manhole for inspection of contacts without lowering oil level.
6. Controls:
  - a. Type: Automatic, solid state.
  - b. Features:
    - i. Adjustable bandwidth and voltage level.
    - ii. High limit/ low limit blocking.
    - iii. Line drop compensation.
    - iv. Proper operation when operated isolated or in parallel and for real and reactive power flow in both directions through transformer.
    - v. Controls for reduction in regulated output voltage of 2-1/2 or 5 percent, either manually at transformer control cabinet or remotely from supervisory control equipment.
    - vi. Local and remote LTC control capability.
  - c. Equipment:
    - i. Current transformer for line drop compensation.
    - ii. Position indicator with drag hands to indicate maximum travel.
    - iii. Limit switches and stops to prevent travel beyond extreme tap position.
    - iv. Crank or hand wheel for manual operation during maintenance.
    - v. Positioning devices and off-position contacts.
    - vi. Operation counter.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:





GUAM POWER  
AUTHORITY

PREPARED BY THE  
ENGINEERING DEPARTMENT

## SPECIFICATION No. E-034

PAGE 17 of 32

JUNE 4, 2024

REV. 6

- vii. Potentiometer for remote position indication to Control Room. Provide potentiometer with 1,280 ohms total resistance and 40 ohms resistance with each LTC step.
- viii. Form C dry contacts wired to RTU for lower limit, upper limit, and hung-up alarms.
- ix. Control circuit protective devices.
- x. Control switches for RAISE-LOWER, AUTOMATIC-MANUAL, and LOCAL-REMOTE.
- xi. OFF-Position contact wired to indicating light in main cabinet.
- xii. Remote control switches for RAISE-LOWER, AUTOMATIC-MANUAL, and a Selsyn type indicator for mounting on the Owner's remote Control Panel.

### 6.4 Drain, Isolating, Vacuum and Filter Valves

- 6.4.1 A two inch, globe type, combination drain and lower filter valve shall be provided. This valve shall have a built-in 3/8 inch sampling device. A one inch upper filter valve shall also be provided.
- 6.4.2 If transformer is designed for vacuum filling, provision shall be made on the top of the tank for a vacuum connection.
- 6.4.3 Isolating valves and other necessary devices shall be provided to allow ready installation and removal of radiators and drainage of oil from radiators without draining oil from the main tank. Drain, filter, vacuum valves and their hand wheel shall be made of bronze.

### 6.5 Lifting Facilities

- 6.5.1 Lifting facilities shall be provided for lifting the cover separately and for lifting the core and coil assembly from the tank using four lifting cables.
- 6.5.2 Lifting facilities shall also be provided for lifting the complete transformer using four slings. The bearing surface shall be free from sharp edges.

### 6.6 Jacking Facilities

Jacking facilities shall be located near the extreme ends of the junctions of the transformer segments. Minimum dimensions and clearances for jacking provisions shall be specified on the outline drawing.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

PREPARED BY THE  
ENGINEERING DEPARTMENT

## SPECIFICATION No. E-034

PAGE 18 of 32

JUNE 4, 2024

REV. 6

### 6.7 Pulling Facilities

Pulling eyes shall be provided for pulling the transformer along center line.

### 6.8 Transformer Base

6.8.1 The transformer base shall be designed to permit rolling or skidding of the transformer in any direction. The base shall be designed so that the transformer center of gravity, as normally prepared for shipment, shall not fall outside the base support for a tilt of the base of 15 degrees from the horizontal, with or without oil in the transformer.

6.8.2 The base shall be fabricated with an adequate number of anchor bolt holes designed to put the transformer base in direct contact, shear and tension, with the transformer concrete foundation at all anchor bolt locations.

Anchorage shall be ASTM A-307 anchor bolts 1" dia. x 16" L with heads embedded in concrete with an ultimate compressive strength of 3000 pounds per square inch. Anchor bolts shall be supplied by manufacturer.

### 6.9 Nameplate

A diagram nameplate shall be furnished and shall be located near eye level above the base of the transformer. The information furnished shall be in accordance with nameplate American National Standard C57.12.00, Section 5.12. The Supplier shall also stamp on the nameplate the Guam Power Authority Purchase Order Number.

### 6.10 Liquid Thermometer

The transformer shall have top oil gauges with alarm contacts and a 0-1 mA output shall be provided for top oil temperature.

### 6.11 Liquid Level Indicator

6.11.1 A magnetic liquid level indicator shall indicate level of insulating liquid. Two electrically separate, normally open alarm contacts shall be provided to indicate both high and low liquid levels.

6.11.2 A third contact shall be provided to trip for low liquid level. This contact shall be electrically isolated from the alarm contacts and shall be set so that the trip operation is at a lower liquid level than the low level alarm.

EFFECTIVE DATE: 2024-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 19 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

### 6.12 Hot Spot Thermometer

A three-stage hottest spot winding temperature indicator relay shall be provided in each winding. The second stage contacts shall be wired in parallel to an auxiliary relay to obtain two (2) normally open contacts in addition to fan control contacts. A 0-1 mA output shall be provided for winding temperature.

The loss of cooling and over temperature trip and alarm scheme shall contain the items listed below.

- a. Auxiliary contacts from second stage of winding temperature relay.
- b. Loss of voltage relay (Device 27-1).
- c. Timing relay to allow enough time for a source transfer before operation (Device 95).
- d. Timing relay with instant transfer auxiliary switch self-resetting, 6-60 minutes, time delay pickup (Device 2-2). The equipment will be used to give an alarm with loss of voltage and high temperature and de-energize the transformer after a set period of time.
- e. Auxiliary time delay relay to give alarm upon loss of voltage to pumps and or fans (Device 27-2).

### 6.13 Sudden Pressure Relay

A sudden pressure relay shall be provided. This relay shall be factory calibrated for the transformer on which the relay is to be used. The relay shall be provided with two electrically separated contacts for alarm and control. The sudden pressure relay shall be provided with an auxiliary lockout relay with hand reset. The auxiliary relay shall have a normally closed contact from the sudden pressure relay shunting the operating coil of the auxiliary lockout relay. The relay shall be suitable for 125 VDC operations. Relay assembly and location shall allow removal with the transformer energized.

### 6.14 Mechanical Pressure Relief Device

A self-sealing, mechanical pressure relief device shall be located on the cover. The relief device shall be furnished with alarm contacts and a visual operation indicator. The indicator shall be resettable with hot-sticks from ground level without the necessity of de-energizing the transformer.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 20 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

### 6.15 Automatic Voltage Regulator (AVR)

Automatic Voltage Regulator (AVR) shall be provided and shall comply with GPA Specification No. E-055.

### 6.16 Fault Gas and Moisture Monitor

Fault gas and moisture monitor shall be GE Power Systems' HYDRAN M2 or newer version. The dissolved gas monitor (DGA) shall be used for continuous and on-line monitoring of moisture and gas-in-oil for the transformer.

The DGA shall have the following features:

- a. Monitoring capability for H<sub>2</sub>, CO, C<sub>2</sub>H<sub>2</sub>, C<sub>2</sub>H<sub>4</sub>, and H<sub>2</sub>O.
- b. Hourly and daily trend with alarm features
- c. History logging of Data and Events
- d. Dry Contacts for alarms
- e. RS232 and Ethernet Connections
- f. DNP 3.0 Protocol
- g. NEMA 4X Enclosure
- h. Analog and Digital Input / Output Card

Two each Hydran M2 sensor, Part No. 16270, shall be provided as spare.

### 6.17 LTC Transformer Oil Filtration System

The load tap changer filtration system shall be OIL FILTRATION SYSTEMS' LTCFS-6-S514D/2-120-N4-B or newer version. The LTC filtration system shall be used for continuous online filtration of dielectric oil of a load tap changer transformer featuring:

- a. High Efficiency Particulate/ Carbon Removal Filter Element, which can remove particles as small as ½ micron in single pass.
- b. Water Removal Element, capable of removing up to 0.25 gals of water.
- c. Element Plugged Indication.
- d. Variable Operation, system can be run continuously or at 1-4 intervals per day via solid state timer.
- e. Automatic Safety Shut-Down and Isolation, if a leak is detected.
- f. Cabinet Oil Leak Detection device.
- g. Stainless Steel Cabinet.
- h. Hour meter.
- i. Inlet Make-Oil Adder Valve.
- j. Flow Sight.
- k. Acid Removal Filter.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:





GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 21 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

### 6.18 Target Type Fault Indicator

The electromagnetic target type fault indicator shall be TK Series, Fuji Electric Ind. Co. Ltd., TKL 200-DC12-B or approved equal. The fault indicator shall have combinations of contacts that are utilized for output, a plug-in type indicating element with visible indication plate, and manual resetting. The indicators shall be installed inside the transformer control cabinet visible through window glass.

### 6.19 Core Ground

It is preferred that the core ground connection be above the oil and accessible from a manhole to facilitate testing of the core to tank insulation without lowering the oil. The connector shall be the slotted type with a captive nut connection. The location of core ground should be indicated on the transformer outline drawing.

### 6.20 Auxiliary Power Source

6.20.1 The auxiliary power will be single-phase 120/240 volt, 60 HZ A/C. The Supplier shall design the transformer cooling system including fans and pumps, LTC motor, controls and accessories to operate on both voltages. The Supplier shall inform GPA of the power requirements needed at the transformer. The terminals provided by the Supplier shall be adequate to receive Guam Power Authority's furnished A/C service conductors.

6.20.2 A 120 VAC, 15 ampere convenience outlet with ground fault protection shall be provided.

6.20.3 Provisions shall be made for an ungrounded 125 VDC incoming supply. All tripping, alarm, and associated devices shall be rated 125 VDC operations.

### 6.21 Centralized Termination and Control Devices Requirement

6.21.1 All equipment alarms, controls, protection and current transformers shall be brought to individual identified terminals centralized in a weather-proof control cabinet mounted on the equipment tank at a center of cabinet to base height of 5 feet 6 inches. Oil thermometer gauge, high voltage winding temperature gauge, and low voltage winding gauge shall also be located inside the weather proof cabinet. Adequate hinged doors shall be provided with weatherproof latching facilities. The latching assemblies shall be operated by handles that can be reached by an operator standing at ground level. Each handle shall have provisions for padlocking and be acceptable for weather-proofing the doors in the closed position.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 22 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

- 6.21.2 All meters and instruments which require resetting shall be mounted less than six (6) feet above the base of the transformer.
- 6.21.3 Alarm contacts shall be electrically separate, open during normal conditions, self-resetting, suitable for closing 5 amperes, carrying 3 amperes continuously, and opening 3 amperes at 125 volts DC.
- 6.21.4 Control contacts shall be electrically separate, open during normal conditions, self-resetting, suitable for closing 30 amperes, carrying 10 amperes continuously, and opening 3 amperes at 125 volts DC.
- 6.21.5 All alarm and control contacts shall be individually wired to the Target Type Fault Indicators TK Series. Another new set of alarm and control contacts shall be individually wired to the GPA Customer (RTU and Relay Panels).

**6.22 Instrument and Control Wiring**

- 6.22.1 THW or THWN wires used by the Supplier shall be of the machine-tool type with 3/64" polyvinyl chloride insulation rated 600 volts, 90-degree C. Other wires with insulation having characteristics which equal or exceed the above requirements for machine-tool type wire are acceptable. Control wire used by the Supplier shall be suitable for wet and dry location, flame retardant, moisture and heat resistant.
- 6.22.2 All secondary wire, regardless of type, shall be stranded. Wire shall have adequate current-carrying capacity. No. 12 AWG shall be used for control circuits, #10 for CT circuits and #18 for SCADA indication.
- 6.22.3 Those portions of any secondary wiring in the control box, or those portions of any secondary or control wiring or cable which pass through conduit, shall not be spliced. However, junction boxes with terminal blocks as specified above may be used to extend secondary wiring passing through conduits.
- 6.22.4 Ring-tongue terminals shall be used for secondary wiring. Spade, slotted spade, flanged spade, and hook terminals are not acceptable. Ring-tongue terminals shall be sufficiently strong to prevent their breakage under conditions of vibration inherent in the equipment in which they are installed.
- 6.22.5 Terminals shall have insulated ferrules whenever the spacing between the terminals, or their projection above or below the terminal board, or both, is such that they can make contact with one another.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

PREPARED BY THE  
ENGINEERING DEPARTMENT

## SPECIFICATION No. E-034

PAGE 23 of 32

JUNE 4, 2024

REV. 6

- 6.22.6 All wires for external connection shall be properly identified and terminated at conveniently located, easily accessible terminal blocks. All terminal blocks furnished by the Supplier shall have No. 10 screws. The screws shall be secured directly into the contact strips and not into nuts embedded in the terminals blocks. The contact strips shall have sufficient thickness to assure that torque applied to the No. 10 screws to hold the terminal to the contact strips will not damage the threads in the tapped holes. The screws shall be firmly secured to the blocks and shall be separated by insulated barriers. Terminal blocks with clamp type fittings are not acceptable.
- 6.22.7 Ring-tongue terminals shall be fastened to the contact strips of terminal blocks with machine screws. Barriers shall separate the contact strips.
- All circuits shall be protected by molded case circuit breakers. Breakers are to be ambient compensated. The breaker size, supplier's name and catalog number are to be shown on the drawings.
- 6.22.8 Ring-tongue terminals shall be fastened to the contact strips of terminal blocks with machine screws. Barriers shall separate the contact strips.
- 6.22.9 Hinge wiring and wiring that will be subjected to bending during maintenance or other operations shall be arranged such that the bending or twisting will be around the longitudinal axis of the wire.
- 6.22.10 Wiring shall not be spliced or tapped. All connections shall be made at the device terminals or on terminal blocks.
- 6.22.11 All future, spare, and unused contacts and devices shall be wired to terminal blocks.
- 6.22.12 A minimum of ten percent (10%) spare terminal points shall be provided.
- 6.22.13 All wirings external to enclosure or cabinet shall be in rigid steel conduits.
- 6.22.14 All wirings from the transformer components to the cabinets, which may require removal for shipment, shall be installed in place and in such a manner that it is only necessary to connect the wires to the cabinets after they are installed on the transformer.
- 6.22.15 Wiring Format
- a. All terminals shall be numbered, and the numbers shall correspond to the numbers on the wiring diagram.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:





GUAM POWER  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 24 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

- b. All wires shall be identified at their termination points with the opposite end designation identification by labeled plastic sleeves or equal. Identification shall correspond to the lettered device, numbered terminal format of the wiring diagrams.

**6.22.16 System Phase Rotation**

The system phase rotation for the island-wide system is GPA C-B-A or NEMA 1-2-3 and all equipment purchased under this contract shall be wired and connected NEMA 1-2-3. All phase markings shall be NEMA 1-2-3. Instrument and relay arrangement shall be 1-2-3 left to right with neutral relays underneath phase grouping. GPA will make the external connections of the incoming and outgoing lines such that GPA C-B-A is connected to NEMA 1-2-3. Phase markings C-B-A shall be reserved for GPA's use.

**7.0 TANK**

- 7.1 The main transformer tank shall be designed to withstand, without permanent deformation, pressures 25 % greater than the maximum operating pressures resulting from the system of oil preservation used. The maximum operating pressures (positive and negative) which the transformer tank is designed to withstand shall be indicated on the nameplate.

**7.2 Vacuum Filling**

If tank is designed for vacuum filling (essentially full vacuum) radiators and auxiliary compartments such as expansion tanks, when not designed for full vacuum filling, shall be so designated and isolating valves shall be provided.

**7.3 Manholes**

Provide one or more circular handholes and at least two circular manholes in the transformer top with neoprene or better gasket material and bolted covers. This facility must be of sufficient size to allow removal of bushing CTs and allow entrance of a person into the transformer tank (24 inch minimum manhole).

**7.4 Ground Pads**

In addition to the surge arrester grounds pads, two ground pads, drilled and tapped for NEMA four-hole (1/2-inch bolts on 1 3/4-inch centers) connectors, shall be installed on diagonally opposite corners of the base. If the base is removable, the two pads shall be installed on the transformer tank wall near the base. Ground pads shall

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:





GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 25 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

be copper-faced steel, stainless steel, or nonferrous pads brazed or welded to the transformer.

### 8.0 TRANSFORMER OIL

The Supplier shall furnish an adequate quantity of mineral oil for the first fill of each transformer. Mineral oil shall be ASTM D3487 Type II. All furnished oil shall be INHIBITED with DBPC (Ditertiary Butyl Para-Cresol). The oil shall have the following minimum characteristics:

- a. Flash Point: Cleveland Open Cup 132 Degrees C.
- b. Fire Point: Cleveland Open Cup 145 Degrees C.
- c. Specific Gravity at 60 Degree F: 0.865 to 0.910.
- d. Viscosity: Saybolt Universal at 100 Degree F - 55 - 63 sec.
- e. Acidity: 0.02 Mg KOH/gm 0.1 max.
- f. Pour Point: -40 Degree F.
- g. Corrosive Sulfur: None
- h. Dielectric Strength (ASTM D877): 26 kV Min.
- i. Power Factor at 68 Degree F: 0.0% Max.
- j. Interfacial Tension: 40 Dynes/CM.
- k. Non-PCB (Polychlorinated Biphenyl) Contaminated:  
Manufacturer is to mark in a permanent manner that the dielectric fluid is "Non-PCB".  
Certified test report on residual oil remaining in the transformer after factory testing that indicates that the oil is free of PCB.

### 9.0 TRANSFORMER COOLING

#### 9.1 Cooling Control

- 9.1.1 A hot-spot dial type thermometer shall be supplied to indicate the maximum hot-spot temperature of the windings. The instrument shall have adjustable alarm contacts and shall be placed at a convenient location, easily readable from ground level. The two stages of cooling shall be activated by the contacts on the dial type hot-spot thermometer. The contacts for cooling control within the hot-spot temperature device shall be readily accessible. This can be accomplished by providing all temperature device windings, oil, etc., with split removable bezel rings.
- 9.1.2 A manual-off-automatic selector switch shall be provided for the control of each stage of cooling equipment. In the "Automatic" position, the cooling equipment shall be activated by the temperature control. In the "manual" position the cooling circuit shall be energized. A contact shall be provided to indicate loss of power to cooling circuits for remote alarm purposes.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 26 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

The contact shall be wired to a terminal strip in the control cabinet for Guam Power Authority's connection. A selector switch shall be provided to allow either cooling stage to be used as the first or preferred system.

- 9.1.3 Operation of the cooling system shall not be made by motor starting switches. If a capacitor is needed for starting, then the motor shall be capacitor start and run.

### 9.2 Heat Exchangers

Heat exchangers must have sufficient capacity to prevent a temperature rise in excess of that specified for each rating of the transformer. Due to severe corrosion problems, GPA prefers heat exchangers made of copper tube and copper fin construction. **ALUMINUM** heat exchangers are **NOT ACCEPTABLE**. Heat exchangers shall be removable from the main tank without the need to drain oil from the main tank.

### 9.3 Radiators

No accessories or pipes shall be installed above the radiators for easy installation and removal during maintenance.

Material of radiator:	Cold rolled Steel, SS41, and 1.0mm thickness	
Internal painting:	Coating with Celerol reaction primer	
Surface preparation:	Grit blasting to Sa 2.5 (SVENSK STANDARD SIS 0559081967) ASTM 2200 D IS 1477 PART 1	
Exterior paint:	Hot-Dip Galvanizing as per ISO-1461	60 Microns
	Epoxy Primer	20 Microns
	Epoxy Intermediate Coat	40 Microns
	Polyurethane Top Coat	<u>40 Microns</u>
	Total Thickness	160 Microns

### 9.4 Cooling Fans

All cooling fans shall be of the low speed type to reduce wind noise levels. Each fan shall be multi-bladed or multi-lobed with one common hub. Fans with more than one hub are not acceptable. Control of the cooling fans shall contain no motor starting switches and shall be plug-in type with an identified separate conductor case ground. Metal to metal ground for fans is not acceptable.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 27 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

**10.0 TESTING:**

- 10.1** The Supplier shall make his plant available to the Guam Power Authority's representatives to inspect the transformer during construction, testing and/or packaging for shipment. Bidder shall include in his bid the factory acceptance test costs witness by the Guam Power Authority, which covers airfare, meals, hotel accommodation, and car rental during the entire testing period.

A factory test plan complete with acceptable reading values shall be submitted to the Guam Power Authority's Engineering Department for approval. The factory test equipment and test methods used shall conform to the applicable requirements of ANSI, NEMA, ASTM, NFPA, and UL standards. Factory tests will be witnessed by three (3) GPA representatives per one (1) each transformer unit.

Manufacturer's technical representative shall be on island to verify transformer connections and acceptance tests.

- 10.2** Two (2) hardcopies and One (1) soft copy in pdf format of certified test reports shall be supplied for the following tests:

1. **Standard Routine Tests** shall be performed as listed in the latest revision of ANSI C57.12.00.
  - a. **Ratio Tests or TTR** on the rated voltage connection and on all tap connections.
  - b. **Polarity and Phase Relation Tests** on the rated voltage connection.
  - c. **Winding Resistance Measurement** shall be performed for each winding. The resistance shall be measured and recorded with hot and cold windings.
  - d. **Winding Insulation Resistance and Polarization Index (PI) Tests** shall be performed for each winding.
  - e. **Core Insulation Resistance Test** shall be measured between the core and ground for duration of 1 minute.
  - f. **Insulation Power Factor Tests and Winding Capacitance Test** shall be performed in accordance with ANSI/IEEE C57.12.90.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:





GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 28 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

### 2. Dielectric Tests

- a. **Lightning Impulse Test** shall be performed in accordance with ANSI/IEEE C57.12.90. Oscillographic records of the test shall be included in the test reports. The minimum height of each individual tract (at maximum deflection) shall be 30 millimeters. Front of Wave Impulse shall be performed. Test sequence shall consist of reduced full wave, full chopped wave, and full wave.
- b. **Low Frequency Test** shall be performed in accordance with ANSI/IEEE C57.12.90. Test shall be performed on auxiliary devices, control, and current transformer circuits.
- c. **Partial Discharge (Corona) Test** at full induced-test voltage level. The measurement shall be less than 500pC at one (1) hour voltage level for 60 minutes. Equipment and general method used shall be in accordance with ANSI/IEEE C57.12.14, C57.12.90, and C57.113.

3. **Audible Sound Level Test** in accordance with NEMA TR-I shall be performed for each stage of cooling.

4. **Regulation, Efficiency, and Losses.** The regulation of each transformer shall be determined for unity (1.0) and eight-tenths (0.8) power factor lagging.

The efficiency and losses of each transformer shall be determined as indicated in the bid data. The guaranteed efficiency and tested total losses shall include losses in all windings.

Measurement of Impedance Voltage, Excitation Current, and Zero-Phase Sequence Impedance shall also be determined.

### 5. Bushing Tests

- a. **Design Tests.** Certification that each type, style, and model bushing furnished has passed the test requirements of ANSI C57.19.00 and ANSI C57.19.01 shall be furnished.

### 6. Other Tests

- a. **Applied Voltage Test** shall be performed to confirm insulation status between windings and between windings and earth. Transformer shall withstand specified voltage during 1 minute.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:





GUAMPower  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 29 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

- b. **Induced Voltage Test** shall be performed to check the insulation status between turns of windings.
- c. **Temperature Rise Tests.** Temperature tests will be required to check the temperature rise of windings.
- d. **Leak Test** shall be performed to check leakage or reduction of pressure from welding points. Transformer is filled with oil and applies N2 gas to tank.
- e. **Dissolved Gas in Oil Analysis Test** shall be performed to check the condition of oil and inside of the transformer using DGA equipment.
- f. **Oil Breakdown Voltage Test** shall be performed by gathering oil samples from the main tank, main conservator, and OLTC tank.
- g. **Dew Point** of the air (or gas) in the tank shall be determined just prior to shipment and at the final shipping destination.

**10.3** The Supplier shall include the following information in the test report.

- a. Winding hot spot temperature rise in degree C, over the average winding temperature rise at the 30 MVA, 65-degree C rating.
- b. Winding Thermal Time Constant.
- c. Type of material used in the primary and secondary winding.

**11.0 LOSS EVALUATION:**

- 11.1** Each bidder shall submit with his bid the guaranteed average load and no-load losses on each transformer submitted on this bid. Guaranteed load losses shall be provided at the transformer's self-cooled (OA) rating and a reference temperature of 85-degree C (65-degree rise + 20-degree C ambient). The requirements and definitions of ANSI Standard C57.12.00, Sections 5.9 and 9.3, shall apply.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 30 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

- 11.2** Guaranteed losses will be evaluated by the Guam Power Authority to determine the equivalent cost for owning and operating each transformer. The value of the transformer no-load and load losses will be determined by GPA at the time of purchase to arrive at the projected Total Cost of Ownership (TCO) as follows:

$$TCO = IC + [A \times (P_o + P_{co})] + [B \times (P_k + P_{cs} - P_{co})] \text{ Where:}$$

- $P_o$  = No Load Losses (NLL) in kW  
 $P_{co}$  = Power Consumption of Cooling Equipment at No Load Operation  
 $P_k$  = Load Losses (LL) in kW  
 $P_{cs}$  = Power Consumption of Cooling Equipment at Rated Power Operation  
 $IC$  = Initial Transformer Cost  
 $A = t \times C_{n/2} \times (1 - (1/(1+i))^n) / i$   
 $B = u \times t \times C_{n/2} \times (1 - (1/(1+i))^n) / i$   
 $u = k^2$   
 $t$  = Operating Hours per Year (24 Hours/Day X 365 Days/Year = 8760 Hrs.)  
 $i$  = Discount Rate (5% Used By GPA for Money Certificates Issued)  
 $n$  = Expected Lifetime of the Transformer in Years (GPA Uses 25 Years)  
 $C_{n/2}$  = Is the Cost of energy at the Mid-Life of the Transformer

Note: If Annual increase of energy price is assumed to be constant,  $c_{n/2}$  can be calculated using  $C$ ,  $j$  &  $n$ .

$$C_{n/2} = (c + (c \times (1+j)^n)) / 2$$

- $c$  = Is the Initial Cost of Energy (\$0.1007) (Calculated from the weighted average energy rate from the Revenue Report with Fuel-Non Fuel Data Dec 2017)  
 $j$  = Is the Annual Increase of Energy Price (1.0985%).  
(Calculated from the Base Rate Increase from 1998 to 2018)  
 $k$  = Is the Average Loading of the Transformer During its Lifetime (32%)  
(Calculated using data from the GPA Substation Analysis 2018)

Note: Load Losses = Total Losses – No Load Losses

EFFECTIVE DATE: **06-04-24**

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

**SPECIFICATION No. E-034**

PAGE 31 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

**11.3** The Manufacturer shall test each transformer for load and no-load losses. This test data shall be certified as correct and submitted to the Authority prior to or at the time of shipment.

**11.4** The Authority will review and consider actual load and no-load losses for each transformer. In the event that the average evaluated losses for like units exceed the average guaranteed losses, the Manufacturer will be penalized at the above rates for the differences. Load and no-load loss penalties will be assessed independently. Bonuses will not be awarded for actual average losses which are less than guaranteed. In addition, any transformer with no-load losses or total losses greater than the tolerances indicated in ANSI Standard C57.12.00 shall be rejected by the Authority.

**12.0 OIL PRESERVATION SYSTEM:**

**12.1** The transformer shall have a conservator (expansion tank) type oil preservation system.

**12.2** There shall be no contact between oil in the expansion tank and air. This shall be accomplished by use of a nitrile air cell (diaphragm not allowed) vented to the outside air. The expansion tank shall be of sufficient volume to operate through an ambient temperature range of minus 35-degree C to plus 50-degree C without causing the low oil level alarm contacts to close at the lower limit and without exceeding the recommended full oil level at the upper limit. A shut-off valve, capable of holding the full head of oil in the expansion tank, shall be provided in the oil line between the expansion tank and the main transformer tank.

**13.0 FINISHING REQUIREMENTS:**

All metal surfaces shall be thoroughly cleaned of rust, welding scale, and grease, and shall be treated to effect a bond between the metal and paint which will prevent the formation of rust under the paint. A priming coat shall be applied immediately after the bonding treatment. A final finish shall consist of two coats of paint. The exterior final coat shall be ANSI 70 Gray.

**14.0 SHIPPING REQUIREMENTS:**

**14.1** Because of severe transportation conditions, the Supplier shall pay particular attention to the proper packaging and bracing of the apparatus to assure its safe arrival. Manufacturer shall install a tilt monitor prior to shipping and results should be within safe recommendations.

**14.2** The Supplier shall prepare all materials and equipment for shipment in such a manner as to protect from damage in transit. All small parts and unit components shall be separately boxed or bundled to prevent galling due to rubbing of one part against another. Each item, box or bundle shall be plainly and individually identifiable for content

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED:



GUAM POWER  
AUTHORITY

## SPECIFICATION No. E-034

PAGE 32 of 32

JUNE 4, 2024

PREPARED BY THE  
ENGINEERING DEPARTMENT

REV. 6

according to item number, GPA P.O. Number, and Supplier's Identifying Number.

- 14.3 A complete itemized Bill of Lading, which clearly identifies and inventories each assembly, sub-assembly, carton, package, envelope, etc., shall be furnished and enclosed with each item or items at the time of shipment.
- 14.4 Openings in the transformer tank or radiators resulting from the removal of parts for shipment shall be identified and securely sealed against the entrance of moisture and foreign materials. Covers shall be of sufficient strength to resist puncture.
- 14.5 Delivery of transformer shall be to actual jobsite as identified by the Guam Power Authority Manager of Engineering.

### 15.0 STATEMENT OF COMPLIANCE:

The Supplier shall provide a signed statement verifying that the products being supplied fully comply with the specification stated herewith. Items not in full compliance with this specification will be identified with a description of the deficiency and any proposed substitutions must be approved by the Guam Power Authority Engineering Department, as described in Section 3.2.1.

### 16.0 WARRANTY:

The Supplier shall warrant the satisfactory and successful operation of the equipment furnished under this specification at the rating, under the conditions, and for the service specified. The Supplier shall further warrant this equipment against defects of design, material and workmanship. All workmanship and parts shall have a warranty of at least (1) year from the date of equipment's commissioning.

EFFECTIVE DATE: 06-04-24

ISSUED:

APPROVED: