



# GUAM SOLID WASTE AUTHORITY

LOURDES A. LEON GUERRERO  
Governor of Guam

JOSHUA F. TENORIO  
Lt. Governor of Guam

IRVIN SLIKE  
General Manager



January 11, 2024

## INVITATION FOR BID GSWA-005-24 INSTALLATION OF ELECTRIC VEHICLE CHARGING STATION

### AMENDMENT NO. 1

1. Amend page 2 of 86

From:

REQUIRED DELIVERY DATE: **120 DAYS**

To now read:

REQUIRED DELIVERY DATE: **150 DAYS**

2. Amend page 2 of 86

From:

This bid shall be submitted in duplicate and sealed to issuing office no later than **(Time) 10:00AM Date: 1/19/2024**, and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

To now read:

This bid shall be submitted in duplicate and sealed to issuing office no later than **(Time) 10:00AM Date: 2/2/2024**, and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

3. Amend page 31 of 86

From:

Bid Due Date & Bid Opening at the Guam Solid Waste Authority Chief of Administration Office at GSWA Office, 2 <sup>nd</sup> Floor, 546 N. Marine Corps Dr. Tamuning, Guam.	Friday, January 19, 2024 at 10:00 AM Chamorro Standard Time
--	---

To now read:

Bid Due Date & Bid Opening at the Guam Solid Waste Authority Chief of Administration Office at GSWA Office, 2 <sup>nd</sup> Floor, 546 N. Marine Corps Dr. Tamuning, Guam.	Friday, February 2, 2024 at 10:00 AM Chamorro Standard Time
--	---



# GUAM SOLID WASTE AUTHORITY

**LOURDES A. LEON GUERRERO**  
Governor of Guam

**JOSHUA F. TENORIO**  
Lt. Governor of Guam

**IRVIN SLIKE**  
General Manager



4. Amend to replace page 32 of 86 with the "Revised 1/11/2024 Page 32 of 86" attached.

\*All others remain the same.

Irvin L. Slike, General Manager

## ACKNOWLEDGEMENT RECEIPT

Return to GSWA by email or fax.

Received By: \_\_\_\_\_

Date: \_\_\_\_\_

Company Name: \_\_\_\_\_

Fax to: 671-649-3777

Email: [procurement@gswa.guam.gov](mailto:procurement@gswa.guam.gov)



# GUAM SOLID WASTE AUTHORITY

LOURDES A. LEON GUERRERO  
Governor of Guam

JOSHUA F. TENORIO  
Lt. Governor of Guam

IRVIN L. SLIKE  
General Manager



## BID SHEET

ITEM #	DESCRIPTION	QUANTITY	UOM	UNIT PRICE	EXTENDED PRICE
1.0	Installation of GSWA's Electric Vehicle Charging Station (Terra 184 - complete and ready to use) As per the following specification:	1	LOT	\$	\$

### SCOPE OF SERVICES:

COMPLY /  
NON-COMPLIANCE

Bidder must install brand new Electric Vehicle (EV) Charging Station, specifically the Terra 184 model at the Layon Landfill in Malojloj, Guam. Charging station will be provided by GSWA

Bidder must have extensive knowledge of Electric Vehicle Supply Equipment (EVSE) and adhere to all safety protocols outlined in the attached installation manual.

Bidder must be an installation engineer and/or master electrician who possess the following qualifications:

- Thorough understanding of the Terra 184 EV charging station.
- Proficiency in high-voltage and high-current electrical installations.
- Compliance with all local regulations and guidelines related to electrical installations.
- Adherence to the installation instructions provided by the manufacturer.

Bidder must provide all necessary labor, tools, equipment, and additional materials or supplies for the installation, such as electrical pipes, conduits, fittings, etc.

Bidder must provide Rigid Galvanized Metal Conduit (RMC).

Bidder must install a 3.5-inch-thick concrete pad with reinforcement to elevate the charging station.

Bidder must provide a non-fusible switch outside near charging station, and NEMA 4X for the box.

Bidder must purchase and install voltage regulator.

Bidder must submit as-built drawing upon completion of work.

Bidder must ensure Charging Station is ready to use upon completion.

Bidder must coordinate with supplier and GSWA for the commissioning of equipment.

Bidder must adhere to all safety standards to guarantee the safe operation of the EV charging station.

Bidder must coordinate with GSWA's designated representative to ensure proper site preparation prior to installation.

Bidder must coordinate with the Guam Power Authority (GPA) if necessary.

Bidder must submit proof of relevant certifications and licenses with bid submission.