INVITATION FOR BID

ISSUING OFFICE:

Guam Power Authority-Procurement Office 1st. Floor, Room 101 Gloria B. Nelson Public Service Building 688 Route 15 Mangilao, Guam 96913

Attn: JOHN M. BENAVENTE, P.E.
General Manager
c/o JAMIE LYNN C. PANGELINAN
Supply Management Administrator

Supply Management Administrator 7/19/2023 for JOHN M. BENAVENTE, P.E. DATE General Manager 07/27/2023 08/03/2023 BID INVITATION NO.: GPA-064-23 DATE ISSUED: BID FOR: Pole Mounted Transformers SPECIFICATION: See Attached **DESTINATION:** Guam Power Authority Dededo Warehouse REQUIRED DELIVERY TIME: See Attached INSTRUCTIONS TO BIDDERS: INDICATE WHETHER: _____ INDIVIDUAL _____ PARTNERSHIP _____ CORPORATION INCORPORATED IN: This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) 9:00 A.M. Date: August 02, 2023 and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details. The undersigned offers and agrees to furnish within the time specified, the articles and services at the price stated opposite the respective items listed on the schedule provided, unless otherwise specified by the bidder. In consideration to the expense of the Government in opening, tabulating, and evaluating this and other bids, and other considerations, the undersigned agrees that this bid remain firm and irrevocable within one hundred twenty (120) calendar days from the date opening to supply any or all of the items which prices are quoted. NAME AND ADDRESS OF BIDDER: SIGNATURE AND TITLE OF PERSON AUTHORIZED TO SIGN THIS BID: AWARD: CONTRACT NO.: ______ AMOUNT: _____ DATE: _____ ITEM NO(S). AWARDED: CONTRACTING OFFICER:

NAME AND ADDRESS OF CONTRACTOR: SIGNATURE AND TITLE OF PERSON

JOHN M. BENAVENTE, P.E.

General Manager

DATE

GUAM POWER AUTHORITY

ATURIDÅT ILEKTRESEDÅT GUÅHAN P.O.BOX 2977 • HAGÅTÑA, GUAM U.S.A. 96932-2977

August 02, 2023

AMENDMENT NO.: I

TO

INVITATION FOR BID NO.: GPA-064-23

FOR

POLE MOUNTED TRANSFORMERS

Prospective Bidders are hereby notified of the following responses and changes to inquiries received from Bidder No. 3 dated July 7, 2023 and Bidder No. 2 dated July 31, 2023

CHANGES:

- Bid Opening Date is changed *FROM* 09:00 A.M., Tuesday, August 02, 2023 (CHamoru Standard Time) *TO NOW READ* 10:00 A.M., Tuesday, August 16, 2023 (CHamoru Standard Time).
- 2. **REMOVE** Page 3 of 50 and **REPLACE** with Page 3a of 50 (see attached)
 - A. Under Invitation for Bid, Instruction to Bidders, Paragraph one has changed **FROM**:

This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) __09:00 A.M.__,

Date: __August 02, 2023 ___ and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

TO NOW READ:

* This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) 10:00 A.M., Date: August 16, 2023 and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

B. Under Date Issued has changed FROM:

DATE ISSUED: 07/27/2023 08/03/2023

TO NOW READ:

* DATE ISSUED: 07/27/2023

- 3. **REMOVE** Page 5, 6, and 7 of 50 and **REPLACE** with Page 5a, 6a, and 7a of 50 (see attached)
 - A. Under Delivery Requirements has changed FROM:
 AIR FREIGHT 6 Weeks After Approved Drawings by Guam Power Authority
 OCEAN FREIGHT 10 Weeks After Approve Drawings by Guam Power Authority

TO NOW READ:

*AIR FREIGHT – 12 Weeks After Approved Drawings by Guam Power Authority
*OCEAN FREIGHT – 14 Weeks After Approve Drawings by Guam Power Authority

B. Under Line item 2.0, A. Specifications A.1 has changed **FROM**:

A.1- Single Phase, Insulation class 15kv, BIL 95kV,

Primary Voltage 13.8kV, Secondary Voltage 120/240 V. without lightning arresters.

TO NOW READ:

* A.1- Single Phase, Insulation class 15kv, BIL 95kV, Primary Voltage 13.8kV, Secondary Voltage 240/480 V. without lightning arresters.

RESPONSE:

Bidder No.: 3 dated 07/27/2023:

QUESTION:

1. I believe the opening date for GPA-064-23 is too soon. We need to ask for a opening date extension by about 2 weeks.

ANSWER:

Kindly see **CHANGES 1 and 2** above.

Bidder No.: 2 dated 07/31/2023:

QUESTION:

- 1. We would like to request for an amendment for subject GPA bid to extend the delivery, as follows:
 - 1. Via Air Freight: 12 weeks instead of 6 weeks
 - 2. Via Ocean freight: 14 weeks instead of 10 weeks

				_	_
Α	N	SI	W	H	R

Kindly see **CHANGES 3** above.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

for JOHN M. BENAVENTE, P.E. General Manager