



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

January 10, 2024

AMENDMENT NO.: II

TO

INVITATION FOR BID NO.: GPA-024-24

FOR

WIRES

Prospective Bidders are hereby notified of the following changes and response to inquiry received from Bidder No.: 2 dated January 05, 2023:

CHANGES:

1. Bid Opening Date is changed *FROM* 10:00 A.M., Thursday, January 11, 2024 (CHamoru Standard Time; ChST) *TO NOW READ* 9:00 A.M., Thursday, January 18, 2024 (CHamoru Standard Time; ChST).
2. *REMOVE* Page 3a of 42 and *REPLACE with* Page 3b of 42 (see attached):

Under Invitation for Bid, Instruction to Bidders, paragraph one has changed

FROM:

This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) 10:00 A.M., Date: 01/11/2024 and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

TO NOW READ:

- This bid shall be submitted in duplicate and sealed to the issuing office above no later than
- * (Time) 9:00 A.M., Date: 01/18/2024 and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

3. *REMOVE* Page 4 of 42 and *REPLACE with* Page 4a of 42 (see attached):

Under Bid Specifications Line Item 1.0, DELIVERY REQUIREMENT is changed

FROM: 8 Weeks After Receipt of Order (ARO)

- * *TO NOW READ:* 15 Weeks After Receipt of Order (ARO)

4. *REMOVE* Page 5 of 42 and *REPLACE with* Page 5a of 42 (see attached):

Under Bid Specifications Line Item 2.0, DELIVERY REQUIREMENT is changed

FROM: 12 Weeks After Receipt of Order (ARO)

- * *TO NOW READ:* 15 Weeks After Receipt of Order (ARO)

RESPONSES:

Bidder No. 2 inquiry dated 01/05/2024:

QUESTION:

1. I'd like to request for change of delivery requirement:

Item 1.0 from 8 weeks ARO to 15 weeks ARO

Item 2.0 from 12 weeks ARO to 15 weeks ARO

ANSWER:

Refer to #3 and #4 of *CHANGES* above.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.



BEATRICE P. LIMTIACO

 General Manager (A)



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

December 29, 2023

AMENDMENT NO.: I

TO

INVITATION FOR BID NO.: GPA-024-24

FOR

WIRES

Prospective Bidders are hereby notified of the following changes and response to inquiries received from Bidder No. 1 dated December 22, 2023, Bidder No.: 2 dated December 28, 2023 and Bidder No.: 3 dated December 28, 2023:

CHANGES:

1. Bid Opening Date is changed *FROM* 10:00 A.M., Thursday, January 04, 2024 (CHamoru Standard Time; ChST) *TO NOW READ* 10:00 A.M., Thursday, January 11, 2024 (CHamoru Standard Time; ChST).
2. *REMOVE* Page 3 of 42 and *REPLACE with* Page 3a of 42 (see attached):

Under Invitation for Bid, Instruction to Bidders, paragraph one has changed

FROM:

This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) 10:00 A.M., Date: 01/04/2024 and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

TO NOW READ:

- * This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) 10:00 A.M., Date: 01/11/2024 and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

RESPONSES:**Bidder No. 1 inquiry dated 12/22/2023:****QUESTION:**

1. Kindly confirm which specifications is your requirement for the Item # 2.0 on the above mentioned bid subject.

9.0

TABLE A

PHASE CONDUCTOR			NEUTRAL-MESSENGER			WEIGHT PER 1000 FEET (Lbs.)	AMPACITY (AMPS)
Size (AWG)	Stranding	Cover Thick (MILS)	Size (AWG)	Stranding	Min. Ultimate Strength (lbs.)	VIP	VIP
DUPLEX							
8	7	45	8	7	610	115.8	84
6	7	45	6	7	959	179.1	110
TRIPLEX							
8	7	45	8	7	610	180.6	84
6	7	45	6	7	959	277.2	110
4	7	45	4	7	1505	429.6	145
2	7	45	4	7	1505	593.7	195
2	7	45	2	7	2360	669.7	195
1/0	19	60	1/0	7	3705	1070.6	260
2/0	19	60	2/0	7	4765	1338.7	300
4/0	19	60	4/0	7	7479	2099.4	395

ANSWER:

Refer to IFB Package Page 12 of 42, GPA Specification No.: E-022, Revision 3, Section 9.0 – TABLE A below:

9.0

TABLE A

PHASE CONDUCTOR			NEUTRAL-MESSENGER			WEIGHT PER 1000 FEET (Lbs.)	AMPACITY (AMPS)
Size (AWG)	Stranding	Cover Thick (MILS)	Size (AWG)	Stranding	Min. Ultimate Strength (lbs.)	VIP	VIP
DUPLEX							
8	7	45	8	7	610	115.8	84
6	7	45	6	7	959	179.1	110
TRIPLEX							
8	7	45	8	7	610	180.6	84
6	7	45	6	7	959	277.2	110
4	7	45	4	7	1505	429.6	145
2	7	45	4	7	1505	593.7	195
2	7	45	2	7	2360	669.7	195
1/0	19	60	1/0	7	3705	1070.6	260
2/0	19	60	2/0	7	4765	1338.7	300
4/0	19	60	4/0	7	7479	2099.4	395
QUADRUPLEX							
6	7	45	6	7	959	375.3	95
4	7	45	4	7	1505	580.0	125
2	7	45	2	7	2360	902.3	165
1/0	19	60	1/0	7	3705	1443.1	225
2/0	19	60	2/0	7	4765	1802.7	260

Bidder No. 2 inquiry dated 12/28/2023:**QUESTION:**

1. May we request for 1 week extension for the bid opening of the subject bid. Holidays have impacted the ability to get quotes back quickly from manufacturers.

ANSWER:

Refer to **CHANGES** above.

Bidder No. 3 inquiry dated 12/28/2023:

QUESTION:

1. Most of our contact are on vacation due to holidays. In this regards, we would like to request for an amendment to extend the bid opening date for following GPA bid:

GPA-024-24 (Wires) – January 19, 2024.

ANSWER:

Refer to **CHANGES** above.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.



BEATRICE P. LIMTIACO
General Manager (A)



INVITATION FOR BID

ISSUING OFFICE:

Guam Power Authority-Procurement Office
1st. Floor, Room 101
Gloria B. Nelson Public Service Building
688 Route 15
Mangilao, Guam 96913

Attn: JOHN M. BENAVENTE, P.E.

General Manager
c/o JAMIE LYNN C. PANGELINAN
Supply Management Administrator


for JOHN M. BENAVENTE, P.E. 12/18/2023
DATE
General Manager

DATE ISSUED: 12/21/2023
12/28/2023 BID INVITATION NO.: GPA-024-24

BID FOR: WIRES

SPECIFICATION: SEE ATTACHED

DESTINATION: GUAM POWER AUTHORITY, DEDEDO SUPPLY WAREHOUSE

REQUIRED DELIVERY TIME: SEE ATTACHED

INSTRUCTIONS TO BIDDERS:

INDICATE WHETHER: INDIVIDUAL PARTNERSHIP CORPORATION

INCORPORATED IN: _____

This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) 10:00 A.M.
Date: 01/04/2024 and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

The undersigned offers and agrees to furnish within the time specified, the articles and services at the price stated opposite the respective items listed on the schedule provided, unless otherwise specified by the bidder. In consideration to the expense of the Government in opening, tabulating, and evaluating this and other bids, and other considerations, the undersigned agrees that this bid remain firm and irrevocable within one hundred twenty (120) calendar days from the date opening to supply any or all of the items which prices are quoted.

NAME AND ADDRESS OF BIDDER:

SIGNATURE AND TITLE OF PERSON
AUTHORIZED TO SIGN THIS BID:

AWARD: CONTRACT NO.: _____ AMOUNT: _____ DATE: _____

ITEM NO(S). AWARDED: _____

CONTRACTING OFFICER:

JOHN M. BENAVENTE, P.E. DATE
General Manager

NAME AND ADDRESS OF CONTRACTOR:

SIGNATURE AND TITLE OF PERSON

