JOSHUA F. TENORIO Lt. Governor of Guam



April 18, 2024

INVITATION FOR BID GSWA-007-24 INSTALLATION OF ELECTRIC VEHICLE CHARGING STATION

Questions and Concerns received from Core Tech International on April 15, 2024

1. Please confirm if the project requires Buy American Act?

Response: No, the Buy American Act does not apply to this project.

2. Please confirm that the contractor is not liable for Tech Rep for the commissioning and training of the charging station?

Response: Contractor is not liable for bringing in a Tech Rep.

3. Please confirm if the contractor will be providing concrete pad for the charging station.

Response: No, the concrete pad is not included in this scope of work.

4. Please confirm which of the charging stations will be installed - Terra 94 or Terra 184?

Response: The charging station to be installed is a Terra 184.

5. Please confirm if the contractor will be providing voltage regulator for the charging station. If yes, the lead time for the voltage regulator will take more than 120 calendar days. We would like to respectfully request the project duration to be extended.

Response: No, a voltage regulator is not required.

As per product specification, 300A is the recommended upstream circuit breaker if Terra 184 will be installed. During site visit, we noticed that Panel H will not be capable to supply the required 300A of the charging station. In line with this, we would like to confirm if we can install a 300A Enclosed Circuit Breaker after the transformer and before the voltage regulator.

Response: Yes, confirmed.

7. We would like to know the government budget for this IFB as this seems to be a re-bid of the previous IFB that we participated in and was cancelled due to budget issues.

Response: We are unable to provide that information.

ACKNOWLEDGEMENT RECEIPT Return to GSWA by email or fax. Received By Date: Company Name: Fax to: 671-649-3777 Email: procurement@gswa.guam.gov

Irvin L. Slike