



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

September 17, 2024

AMENDMENT NO.: II
TO
INVITATION FOR BID NO.: GPA-103-24
FOR
PAD MOUNTED TRANSFORMERS

Prospective Bidders are hereby notified of the following response to an inquiry received from Bidder No. 2 dated September 16, 2024:


QUESTION:

1. My supplier is asking for GPA to confirm the winding material: aluminum or copper.

ANSWER:

There is no preference in the winding materials. As long as they meet the DOE standards and impedance standards set by the GPA specifications.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.


JOHN M. BENAVENTE, P.E.
General Manager 