



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUAHAN
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

March 28, 2025

AMENDMENT NO.: I

TO

INVITATION FOR BID NO.: GPA-040-25

FOR

WIRES

Prospective Bidders are hereby notified of the following response to an inquiry received from Bidder No. 1 dated March 21, 2025:

QUESTION:

- My supplier has a question:
Can you please ask GPA to clarify the reels required for Item 2?

<p>2.0 Wire</p> <p>A. SPECIFICATIONS: A.1 500 KCMIL Copper A.2 600 V A.3 Single Conductor</p> <p>As per GPA Specification No.: E-024 Revision 5 GPA Index No.: SSUW1423</p> <p>B. PACKAGING QUANTITY: B.1 1,000 Feet per Wooden Reel</p> <p>C. MARKING REQUIREMENTS: C.1 Stencil 1" GPA Index No./ Purchase Order No./ Footage per Reel/ Date MFG/ Batch No./ Reel No. Net Weight/ Gross Weight. C.2 Wire certification is to be included with shipment and invoice. C.3 Vendors are responsible to de-van materials from containers.</p>	<p>2,000 FT.</p> <p>\$ _____</p> <p>COMPLY:</p> <p>Comply must be identified below. All deviation must be identified below.</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p>	<p>\$ _____</p> <p>NOT COMPLY:</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p>
--	---	--

But Spec E-24 says steel reels.


6.4 REELS

6.4.1 The inner drum end of the cable, when allowed to project through the flange of the reel shall be protected to avoid injury to the cable or cable seal.

6.4.2 Reels shall be designated to support the weight of the cable and withstand handling in accordance with industry practices. Reels shall be steel.

6.4.3 The mandrel hole size shall be three inches, minimum.

EFFECTIVE DATE: 5-22-24 ISSUED: [Signature] APPROVED: [Signature]

 GUAM POWER AUTHORITY PREPARED BY THE ENGINEERING DEPARTMENT	SPECIFICATION No. E-024	Page 5 of 6
		May 22, 2024
		REV. 5

6.4.4 A durable, non-fading label shall be securely attached to a flange of the reel. The label shall plainly indicate the following:

- A. GPA Purchase Order number
- B. Shipping length in feet of the cable on the reel
- C. Beginning and ending sequential footage number
- D. Number, type, thickness and size of conductor
- E. Thickness and type of insulation
- F. Voltage rating
- G. Tare weight

ANSWER:

The Authority requires two different types of reels for certain wires. For this particular wire, we are requesting that the wires are packaged and spooled on a wooden reel as these wires are stored in the warehouse.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

[Signature] JOHN M. BENAVENTE, P.E.
General Manager
[Signature]