



# GUAM POWER AUTHORITY

ATURIDÂT ILEKTRESEDÂT GUÅHAN  
P.O.BOX 2977 • HAGÂTÑA, GUAM U.S.A. 96932-2977

October 03, 2024

AMENDMENT NO.: X

TO

INVITATION FOR BID NO.: GPA-069-24

FOR

VACUUM CIRCUIT BREAKERS

Prospective Bidders are hereby notified of the following changes and response to Bidder No. 1 inquiry dated 09/26/2024:

**INCLUSIONS:**

1. Diagram: Attachment C
2. Diagram: Attachment D

**RESPONSE:**

**Bidder No. 1 inquiry date 09/26/2024:**

**QUESTION:**



1. Regarding your reply to the spare auxiliary contacts, the manufacturer says they can provide 4 additional spare auxiliary contacts (2a and 2b), but the secondary block location would need to be defined by GPA, so they match with what they have in the cubicle.

**ANSWER:**

The four contacts will suffice. Please see the attached diagrams for existing setup. The Agana one is for the GE equivalent and the P220 one is for the Federal Pacific equivalent.

Please refer to ***INCLUSIONS Nos. 1 and 2 above.***

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
J. M. BENAIVER  
General Manager 



# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN  
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

September 30, 2024

AMENDMENT NO.: IX

TO

INVITATION FOR BID NO.: GPA-069-24

FOR

VACUUM CIRCUIT BREAKERS

Prospective Bidders are hereby notified of the following:

**CHANGES:**

1. Bid Opening Date is changed **FROM** 10:00 A.M., Tuesday, October 01, 2024 (CHamoru Standard Time) **TO NOW READ** 10:00 A.M., Tuesday, October 15, 2024 (CHamoru Standard Time).

**REMOVE** Page 3g of 37 and **REPLACE** with Page 3h of 37 (see attached)

A. Under **INVITATION FOR BID, INSTRUCTION TO BIDDERS**, verbiage is changed




**FROM:**

This bid shall be submitted in duplicate and sealed to the issuing office above no later than **(Time) 10:00 A.M., Date: October 01, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

**TO NOW READ:**

- \* This bid shall be submitted in duplicate and sealed to the issuing office above no later than **(Time) 10:00 A.M., Date: October 15, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
 JOHN M. BENAVENTE, P.E.  
General Manager 



# GUAM POWER AUTHORITY

ATURIDÂT ILEKTRESEDÂT GUÅHAN  
P.O.BOX 2977 • HAGÂTÑA, GUAM U.S.A. 96932-2977

September 24, 2024

AMENDMENT NO.: VIII  
TO  
INVITATION FOR BID NO.: GPA-069-24  
FOR  
VACUUM CIRCUIT BREAKERS

Prospective Bidders are hereby notified of the following change and response to Bidder No.1 inquiry dated 08/23/2024:

**CHANGES:**

1. Bid Opening Date is changed **FROM** 11:00 A.M., Wednesday, September 25, 2024 (CHamoru Standard Time) **TO NOW READ** 10:00 A.M., Tuesday, October 01, 2024 (CHamoru Standard Time).

**REMOVE** Page 3f of 37 and **REPLACE** with Page 3g of 37 (see attached)

A. Under **INVITATION FOR BID, INSTRUCTION TO BIDDERS**, verbiage is changed

**FROM:**

This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) **11:00 P.M., Date: September 25, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall Be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

**TO NOW READ:**

- \* This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) **10:00 A.M., Date: October 01, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall Be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

**RESPONSE:**

**Bidder No. 1 inquiry date 08/23/2024:**




**QUESTION:**

1. We received the mark up drawings A & B per your Amendment I and GPA is requesting to "add spare Auxiliary switch contact". Per manufacturer, this auxiliary switch contact are not part of the vacuum circuit breaker. We can include this to be field installed by GPA on existing switchgear cubicle, however please provide the Qty., manufacturer's name and catalog number so we can get the price.

**ANSWER:**

The Spare Auxiliary contacts referred to in the mark-up on the drawing were not intended to be taken as external Mechanism-Operated Control (MOC) auxiliary switches which the vendor appears to have thought. What the Authority requires are spare "a" and "b" contacts which should be part of the breaker. GPA usually require a minimum of 10 each "a" and 10 each "b" contacts connected to the mechanism of each breaker. These shall be wired to terminal blocks on the breakers.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
 JOHN M. BENAVENTE, P.E.  
General Manager 



# GUAM POWER AUTHORITY

ATURIDÂT ILEKTRESEDÂT GUÅHAN  
P.O.BOX 2977 • HAGÂTNÂ, GUAM U.S.A. 96932-2977

September 19, 2024

AMENDMENT NO.: VII

TO

INVITATION FOR BID NO.: GPA-069-24

FOR

VACUUM CIRCUIT BREAKERS

Prospective Bidders are hereby notified of the following changes and response to Bidder No. 1 inquiry dated 08/23/2024:

**CHANGES:**

1. **REMOVE** Page 4a of 37 and **REPLACE** with Page 4b of 37 (see attached):

a. Under **INVITATION FOR BID, DESCRIPTION, A. SPECIFICATION – A.12** has changed

**FROM:**

Current Transformer Ratio: 1200:5

**TO NOW READ:**

\* Deleted

2. **REMOVE** Page 6a of 37 and **REPLACE** with Page 6b of 37 (see attached):

a. Under **INVITATION FOR BID, DESCRIPTION, A. SPECIFICATION – A.12** has changed

**FROM:**

Current Transformer Ratio: 1200:5

**TO NOW READ:**

\* Deleted

**RESPONSE:**

**Bidder No. 1 inquiry date 08/23/2024:**

**QUESTION:**

- Item A12 of page 4a & 6a (1200:5A CT) -. Per manufacturer, the CT's are not part of the vacuum breaker. However, we can include the CT's to be field installed by GPA on existing switchgear cubicle. Please provide the Qty and specs of this CT (i.e BIL rating, nominal system voltage, Design form whether window type, wound type, etc, rating factor, metering accuracy, relaying accuracy, window size if applicable, frequency 60HZ?).



# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN  
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

September 16, 2024

AMENDMENT NO.: VI

TO

INVITATION FOR BID NO.: GPA-069-24

FOR

VACUUM CIRCUIT BREAKERS

Prospective Bidders are hereby notified of the following:

**CHANGES:**

1. Bid Opening Date is changed **FROM** 11:00 A.M., Wednesday, September 18, 2024 (CHamoru Standard Time)  
**TO NOW READ** 11:00 A.M., Wednesday, September 25, 2024 (CHamoru Standard Time).

**REMOVE** Page 3e of 37 and **REPLACE** with Page 3f of 37 (see attached)

A. Under **INVITATION FOR BID, INSTRUCTION TO BIDDERS**, verbiage is changed

**FROM:**

This bid shall be submitted in duplicate and sealed to the issuing office above no later than **(Time) 11:00 P.M., Date: September 18, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall Be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

**TO NOW READ:**

- \* This bid shall be submitted in duplicate and sealed to the issuing office above no later than **(Time) 11:00 A.M., Date: September 25, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall Be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

JOHN M. BENAVENTE, P.E.  
General Manager

**ANSWER:**

Please refer to No.1. a. of **CHANGES** above.



**QUESTION:**

2. We received the mark up drawings A & B per your Amendment I and GPA is requesting to "add spare Auxiliary switch contact". Per manufacturer, this auxiliary switch contact are not part of the vacuum circuit breaker. We can include this to be field installed by GPA on existing switchgear cubicle, however please provide the Qty, manufacturer's name and catalog number so we can get the price.

**ANSWER:**

Please refer to No. 2. a. of **CHANGES** above.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
JOHN M. BENAVENTE, P.E.  
General Manager 

Attn: JOHN M. BENAVENTE, P.E.  
General Manager  
c/o JAMIE LYNN C. PANGELINAN  
Supply Management Administrator

NAME AND ADDRESS OF CONTRACTOR:	SIGNATURE AND TITLE OF PERSON
_____	
_____	





# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN  
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

August 28, 2024

AMENDMENT NO.: IV

TO

INVITATION FOR BID NO.: GPA-069-24

FOR

VACUUM CIRCUIT BREAKERS

Prospective Bidders are hereby notified of the following:

**CHANGES:**

1. Bid Opening Date is changed **FROM** 3:00 P.M., Thursday, August 29, 2024 (CHamoru Standard Time) **TO NOW READ** 11:00 A.M., Thursday, September 05, 2024 (CHamoru Standard Time).

**REMOVE** Page 3c of 37 and **REPLACE** with Page 3d of 37 (see attached)

A. Under **INVITATION FOR BID, INSTRUCTION TO BIDDERS**, verbiage is changed



**FROM:**

This bid shall be submitted in duplicate and sealed to the issuing office above no later than **(Time) 3:00 P.M., Date: August 29, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

**TO NOW READ:**

- \* This bid shall be submitted in duplicate and sealed to the issuing office above no later than **(Time) 11:00 A.M., Date: September 05, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
JOHN M. BENAVENTE, P.E.  
General Manager 



# GUAM POWER AUTHORITY

ATURIDÂT ILEKTRESEDÂT GUÅHAN  
P.O.BOX 2977 • HAGÂTÑA, GUAM U.S.A. 96932-2977

August 22, 2024

AMENDMENT NO.: III

TO

INVITATION FOR BID NO.: GPA-069-24

FOR

VACUUM CIRCUIT BREAKERS

Prospective Bidders are hereby notified of the following:

**CHANGES:**

1. Bid Opening Date is changed **FROM** 11:00 A.M., Thursday, August 22, 2024 (CHamoru Standard Time) **TO NOW READ** 3:00 P.M., Thursday, August 29, 2024 (CHamoru Standard Time).

**REMOVE** Page 3b of 37 and **REPLACE** with Page 3c of 37 (see attached)

A. Under **INVITATION FOR BID, INSTRUCTION TO BIDDERS**, verbiage is changed




**FROM:**

This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) **11:00 A.M.**, **Date: August 22, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

**TO NOW READ:**

- \* This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) **3:00 P.M.**, **Date: August 29, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
 JOHN M. BENAVENTE, P.E.  
General Manager 



# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN  
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

August 19, 2024

AMENDMENT NO.: II

TO

INVITATION FOR BID NO.: GPA-069-24

FOR

VACUUM CIRCUIT BREAKERS

Prospective Bidders are hereby notified of the following:

**CHANGES:**

1. Bid Opening Date is changed **FROM** 11:00 A.M., Tuesday, August 20, 2024 (CHamoru Standard Time) **TO NOW READ** 11:00 A.M., Thursday, August 22, 2024 (CHamoru Standard Time).

**REMOVE** Page 3a of 37 and **REPLACE** with Page 3b of 37 (see attached)

A. Under **INVITATION FOR BID, INSTRUCTION TO BIDDERS**, verbiage is changed

**FROM:**

This bid shall be submitted in duplicate and sealed to the issuing office above no later than **(Time) 11:00 A.M., Date: August 20, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

**TO NOW READ:**

- \* This bid shall be submitted in duplicate and sealed to the issuing office above no later than **(Time) 11:00 A.M., Date: August 22, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

JOHN M. BENAVENTE, P.E.  
General Manager



# GUAM POWER AUTHORITY

ATURIDÂT ILEKTRESEDÂT GUÅHAN  
P.O.BOX 2977 • HAGÂTÑA, GUAM U.S.A. 96932-2977

August 14, 2024

## AMENDMENT NO.: I

TO

INVITATION FOR BID NO.: GPA-069-24

FOR

## VACUUM CIRCUIT BREAKER

Prospective Bidders are hereby notified of the following changes and responses to inquiries received from Bidder No. 1 dated May 15, 2024 and May 24, 2024:

### CHANGES:

- \* 1. Bid Opening Date is changed **FROM** 10:00 A.M., Thursday, May 16, 2024 (CHamoru Standard Time) **TO NOW READ** 11:00 A.M., Tuesday, August 20, 2024 (CHamoru Standard Time).
- 2. **REMOVE** Page 3 of 37 and **REPLACE** with Page 3a of 37 (see attached):
  - a. Under Invitation for Bid, Instruction for Bidders, Paragraph one has changed

#### **FROM:**

This bid shall be submitted in duplicate and sealed to the issuing office above no later than **(Time) 10:00 A.M., Date: May 16, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

#### **TO NOW READ:**

- \* This bid shall be submitted in duplicate and sealed to the issuing office above no later than **(Time) 11:00 A.M., Date: August 20, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

- b. Under Invitation for Bid, REQUIRED DELIVERY TIME is changed

#### **FROM:**

26 Weeks After Receipt of Order (ARO)

#### **TO NOW READ:**

- \* 32 Weeks After Receipt of Order (ARO)

3. **REMOVE** Pages 4 and 6 of 37 and **REPLACE** with Pages 4a and 6a of 37 (see attached):

Under Invitation for Bid, **DESCRIPTION, DELIVERY REQUIREMENT** is changed

**FROM:**

26 Weeks After Receipt of Purchase Order (ARO)

**TO NOW READ:**

\* 32 Weeks After Receipt of Purchase Order (ARO)

**Bidder No.: 1 dated 05/15/2024:**

**QUESTION:**

1. Per below message from our US supplier, we would like to request for an amendment to extend the bid opening date to May 24.

Please also provide the drawings/photos of the existing circuit breakers so that they can match them exactly.

**ANSWER:**

- a. Kindly refer to No. 1 and 2 a. of **CHANGES** above.
- b. Kindly refer Attachment A and B.

**Bidder No.: 1 dated 05/24/2024:**

**QUESTION:**



1. As per quote received from our US supplier, the lead time from the factory is 28 weeks ex-factory plus 10 days shipping from factory to US West Coast plus 2-weeks shipping from US West Coast to Guam plus 1-week Guam custom clearing and delivery to your GPA warehouse.

In this regard, we would like to request for an amendment to extend the delivery to 32 weeks.

**ANSWER:**

Kindly refer to No. 2 b. and 3 of **CHANGES** above.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
JOHN M. BENAVENTE, P.E.  
General Manager 

# INVITATION FOR BID

**ISSUING OFFICE:**

Guam Power Authority-Procurement Office  
1st. Floor, Room 101  
Gloria B. Nelson Public Service Building  
688 Route 15  
Mangilao, Guam 96913

**Attn:** JOHN M. BENAVENTE, P.E.  
General Manager  
c/o JAMIE LYNN C. PANGELINAN  
Supply Management Administrator

for n=1

4/30/2024

**JOHN M. BENAVENTE, P.E.**      **DATE**  
**General Manager**

DATE ISSUED: **05/09/2024** BID INVITATION NO.: GPA-069-24

BID FOR: Vacuum Circuit Breaker

SPECIFICATION: See Attached

DESTINATION: Guam Power Authority, Dededo Warehouse

REQUIRED DELIVERY TIME: 26 Weeks After Receipt of Order (ARO)

**INSTRUCTIONS TO BIDDERS:**

INDICATE WHETHER:

	INDIVIDUAL	PARTNERSHIP	CORPORATION
--	------------	-------------	-------------

INCORPORATED IN:

This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) 10:00 A.M.,  
**Date: May 16, 2024** and shall be publicly opened. Bid submitted after the time and date specified above shall be  
 rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

The undersigned offers and agrees to furnish within the time specified, the articles and services at the price stated opposite the respective items listed on the schedule provided, unless otherwise specified by the bidder. In consideration to the expense of the Government in opening, tabulating, and evaluating this and other bids, and other considerations, the undersigned agrees that this bid remain firm and irrevocable within one hundred twenty (120) calendar days from the date opening to supply any or all of the items which prices are quoted.

NAME AND ADDRESS OF BIDDER: \_\_\_\_\_ SIGNATURE AND TITLE OF PERSON  
AUTHORIZED TO SIGN THIS BID: \_\_\_\_\_

---

---

---

---

ITEM NO(S). AWARDED:

CONTRACTING OFFICER:

JOHN M. BENAVENTE, P.E.      DATE  
General Manager

NAME AND ADDRESS OF CONTRACTOR: \_\_\_\_\_ SIGNATURE AND TITLE OF PERSON \_\_\_\_\_