



GUAM POWER AUTHORITY

ATURIDÂT ILEKTRESEDÂT GUÅHAN
P.O.BOX 2977 • HAGÂTNÂ, GUAM U.S.A. 96932-2977

September 2, 2025

AMENDMENT NO.: II

TO

INVITATION FOR BID NO.: GPA-070-25

FOR

PAD MOUNTED TRANSFORMERS

Prospective Bidders are hereby notified of the following and response to an inquiry received from Bidder No.: 6 dated August 29, 2025:

QUESTION:

1. We would like to clarify these specifications below.

According to the specification, the transformer requires a sealed welded cover. However, in Appendix A, line-item no. 21 (page 27), it states a flip-top hood is required. Kindly confirm which type of cover is applicable for this three-phase pad-mounted transformer.


9.0 CONSTRUCTION

- 9.1 The transformer shall consist of a welded transformer tank which shall be sealed with a welded cover. The enclosure, tank, doors and base of the transformer (the part that makes contact with the mounting surface) shall be made of Type 304L stainless steel.

ANSWER:

The response shall be "no" due to the bid specifications does not require a flip top.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.


JOHN M. BENAVENTE, P.E.
General Manager 