October 31, 2025

## INVITATION FOR BID GSWA-001-26 ELECTRICAL DESIGN & INSTALLATION FOR NEW BIODIESEL PRODUCTION EQUIPMENT

## **Ouestions and Concerns received from Planate Management Group LLC on October 27, 2025**

1. We hope this can be utilized for the As-Builts. Our IT created an external folder for the As-Builts, if you could drop the file in here it will save travel time to pick up a thumb drive.

<u>Response:</u> As- builts can be downloaded by clicking this link <a href="https://drive.google.com/file/d/1eUBmJx">https://drive.google.com/file/d/1eUBmJx</a> nx zqZ3-Gd9SosDgmoEwsXibi/view?usp=sharing

## Questions and Concerns received from Planate Management Group LLC on October 29, 2025

 Our team is unable to commence design activities without confirmation from GPA regarding the transformer location and available capacity. Kindly confirm the contract period will be extended accordingly until the required information is received from GPA.

<u>Response:</u> To prevent construction delays, GSWA has opted to temporarily use the emergency generator power supply independently. The connection to the GPA power supply will be put out for bid at a later date to ensure timely project completion. See Amendment No. 3

2. To ensure delivery of a quality and complete design package to the client, we estimate that the design effort will require approximately twenty (20) working days. Please confirm if this timeline is acceptable.

Response: GSWA has agreed to grant eighteen (18) calendar days for completion of the design. See Amendment No. 3

3. Please confirm the as-built drawings will be provided in digital format for our reference and use in the design process.

Response: Yes, GSWA will provide the as-built drawings in digital form. See link provided in response to Question #1 on October 27, 2025 above.

**Irvin L. Slike,** General Manager

ACKNOWLEDGEMENT RECEIPT Return to GSWA by email or fax.
Received By:
Date:
Company Name:
Fax to: 671-649-3777
Email: procurement@gswa.guam.gov