



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

February 10, 2026

AMENDMENT NO.: I
TO
INVITATION FOR BID NO.: RE-BID GPA-044-25
FOR
DATA TRANSPORT AIR FIBER

Prospective Bidders are hereby notified of the following responses to inquiries received from Bidder No.: 3 dated February 5, 2026:

QUESTION:

1. For the UPS Systems in A.8, is there 120V AC outlets at all sites to support all UPS's?

ANSWER:

If the equipment/device can operate on 48VDC or 130VDC there is no need for UPS. All sites have 130VDC and/or 48VDC power.

QUESTION:

2. What is the required/expected back-up runtime of the UPS?

ANSWER:

4 hours.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.


JOHN M. BENAVENTE, P.E.
General Manager 