



GUAM SOLID WASTE AUTHORITY

LOURDES A. LEON GUERRERO
Governor of Guam

JOSHUA F. TENORIO
Lt. Governor of Guam

IRVIN L. SLIKE
General Manager



February 19, 2026

INVITATION FOR BID GSWA-009-26 ULTRA-LOW SULFUR DIESEL

AMENDMENT NO. 2

1. Amend page 29
From:

Deadline for Receipt of Written Questions must be e-mailed to the Guam Solid Waste Authority at procurement@gswa.guam.gov , ATTN: General Manager	Monday, February 9, 2026 on or before 5:00PM Chamorro Standard Time
Bid Due Date & Bid Opening at the Guam Solid Waste Authority: Superintendent's Office, GSWA Bldg., 1st Floor, 546 N. Marine Corps Dr., Tamuning, Guam	Monday, February 23, 2026 at 10:00AM Chamorro Standard Time

To now read:

Deadline for Receipt of Written Questions must be e-mailed to the Guam Solid Waste Authority at procurement@gswa.guam.gov , ATTN: General Manager	Monday, February 23, 2026 on or before 5:00PM Chamorro Standard Time
Bid Due Date & Bid Opening at the Guam Solid Waste Authority: Superintendent's Office, GSWA Bldg., 1st Floor, 546 N. Marine Corps Dr., Tamuning, Guam	Friday, February 27, 2026 at 10:00AM Chamorro Standard Time

2. Amend to replace page 30 with "Revised 2/19/2026" Page 30 attached.

*All others remain the same.

Irvin L. Slike,
General Manager

ACKNOWLEDGEMENT RECEIPT Return to GSWA by email or fax.	
Received By:	_____
Date:	_____
Company Name:	_____
Fax to: 671-649-3777	
Email: procurement@gswa.guam.gov	



GUAM SOLID WASTE AUTHORITY

LOURDES A. LEON GUERRERO
Governor of Guam

JOSHUA F. TENORIO
Lt. Governor of Guam

IRVIN L. SLIKE
General Manager



GSWA-009-26 ULTRA-LOW SULFUR DIESEL

GENERAL:

The contractor shall supply ultra-low sulfur diesel (ULSD) intended exclusively for use in landfill heavy equipment. The equipment is not designed for road travel. GSWA maintains a ConVault storage tank with a 12,000-gallon capacity for this purpose. Delivery shall be made directly to the Layon Landfill, and the bidder is responsible for providing all necessary safety hook-up fittings required for secure fuel transfer to the ConVault tank. All fueling operations must comply with applicable local and federal safety and environmental regulations.

This is an **“Indefinite Quantity Bid”**. The quantities reflected are annual estimated requirements projected within a twelve (12) month period. These amounts may increase during the term of this bid. However, regardless of the fluctuation of quantities, this bid shall be subject to the availability of funds.

For the purpose of bid evaluation and price extension, GSWA has determined a Bid Reference Price of \$1.927 per gallon, calculated according to the FOB Singapore Posting. This reference price is exclusively utilized for evaluation and does not constitute the contract price. Bidders are required to submit a fixed premium price per gallon, which will be added to the Bid Reference Price. The Bid Reference Price is not subject to modification by bidders and should remain unchanged. Actual invoices will reflect the applicable published market index at the time of delivery, combined with the awarded Fixed Premium Price per gallon.

The price submitted by each bidder must be a fixed per-gallon premium, valid throughout the contract period. For each delivery, the invoiced amount to GSWA shall consist of the published market index price for ULSD on the delivery date, plus the bidder’s specified fixed premium per gallon.

BID SHEET:

1.0 ULTRA-LOW SULFUR DIESEL

BID REFERENCE PRICE:		FIXED PREMIUM PRICE:		TOTAL UNIT PRICE:
\$1.927	+	\$ _____	=	\$ _____
TOTAL UNIT PRICE		QTY/UOM		TOTAL BID PRICE
\$ _____	x	30,000 GALLONS	=	\$ _____

SPECIFICATIONS:

The Ultra-Low Sulfur Diesel (ULSD) fuel supplied under this contract shall comply with all applicable federal and local laws and regulations, including the requirements set forth in Guam Public Law 30-184, which mandates the use of ULSD in Guam. All fuel delivered shall meet the ULSD standard currently in effect.

Bidder must be able to deliver 2,500 gallons per month, within 24 to 48 hours of request to the Layon Landfill

The storage, handling, and transfer of all liquid fuels supplied under this contract shall comply with all applicable federal and local safety and environmental regulations, including OSHA standards under 29 CFR §1910.106 (Flammable and Combustible Liquids) and the current edition of the National Fire Protection Association (NFPA) Flammable and Combustible Liquids Code (NFPA 30).

COMPLY/ NON-COMPLIANCE
