



GUAM SOLID WASTE AUTHORITY

LOURDES A. LEON GUERRERO
Governor of Guam

JOSHUA F. TENORIO
Lt. Governor of Guam

IRVIN SLIKE
General Manager



February 26, 2026

INVITATION FOR BID GSWA-007-26 3,000-GALLON CHEMICAL STORAGE TANK

Questions and Concerns received from Pacific Revolution Corp on February 25, 2026

1. The need for more information from Methanol Specified Manufacturer in regards to whether the HDLPE or the XLPE material tank is an approved Long Term Storage Solution or if a Stainless Steel or Steel material tank is advised
Answer: Please see Amendment No. 2

2. Supplier is proposing a Stainless Steel or Steel Variation tank for proper Long Term Storage, if this will be acceptable to bid
Answer: Please see Amendment No. 2

3. Supplier is questioning whether proper grounding for these tanks have been established to prevent static electricity from igniting highly flammable Methanol contents
Answer: Yes, GSWA can confirm that proper grounding will be established

4. Supplier does not offer an option for a temperature monitor, and must be outsourced from another supplier, and need additional time to look for a supplier that supplies one that can be used with this specific tank
Answer: Bid Submission deadline is extended. Please see Amendment No. 2

5. Supplier will not honor warranty in regards to HDLPE or XLPE Tanks being used due to storage of Methanol and how it will break down the plastic materials of the tank itself causing structural integrity of tank to eventually deteriorate and cause accidental leakage or explosion
Answer: Tank requirement to be Stainless Steel. Please see Amendment No. 2

6. Due to the specific chemical being used, there are concerns to the safety of the surroundings and most especially personnel using these plastic made tanks. Please advise
Answer: Tank material requirement is Stainless Steel. GSWA will take all necessary precautions regarding the safety of personnel and surrounding areas.

Irvin L. Slike,
General Manager

ACKNOWLEDGEMENT RECEIPT Return to GSWA by email or fax.

Received By: _____
Date: _____
Company Name: _____

Fax to: 671-649-3777
Email: procurement@gswa.guam.gov