

SHIP TO: <b>CIF DEDEDO WAREHOUSE (CIF)</b>  RECEIVING SECTION:  GPA DEDEDO WAREHOUSE 483A EAST MARINE DRIVE ROUTE 1 DEDEDO, GUAM 96929 PLEASE CALL (671) 635-2073/2074/2077 PRIOR TO ALL DELIVERIES	<b>PURCHASE ORDER</b>   <b>GUAM POWER AUTHORITY</b> ATURIDÁT ILEKTRESEDÁT GUÅHAN P.O. Box 2977 Hagatna, Guam 96932	THIS PURCHASE ORDER NUMBER  <b>34663</b>  MUST APPEAR ON ALL INVOICES. PACKING SLIPS, PACKAGES, B/L, CORRESPONDENCE, ETC.				
Transformer  DDREYES <span style="float: right;"><i>Dp</i></span>	TELEPHONE: (671) 648-3054/5 FAX: (671) 648-3165	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%;">PO DATE</td> <td style="width:50%;">JOB ORDER NO./OBJ</td> </tr> <tr> <td style="text-align: center;">1/15/2026</td> <td style="text-align: center;">59900.154100</td> </tr> </table>	PO DATE	JOB ORDER NO./OBJ	1/15/2026	59900.154100
PO DATE	JOB ORDER NO./OBJ					
1/15/2026	59900.154100					

<b>V E N D O R</b>	Vendor Number: <b>7493</b>  JMI EDISON P O BOX 6577 TAMUNING, GUAM 96911  TEL: (671) 646-6400 FAX: (671) 649-4835 EMAIL: <a href="mailto:isdsales@jmiguam.com">isdsales@jmiguam.com</a> <a href="mailto:romeooriondo@jmiguam.com">romeooriondo@jmiguam.com</a> <a href="mailto:richardmesa@jmiguam.com">richardmesa@jmiguam.com</a>	AUTHORITY: 3109 INVITATION NO.: GPA-080-25 CONTRACT NO.: C-080-25 TIME FOR DELIVERY: 24 Weeks After Approved Drawings by Guam Power Authority <span style="float: right;"><b>08/25/2026</b></span> COMPLETION: EXPIRATION: DISCOUNT TERMS: REQUISITION NO: 40279 OR
--	---	---

NO.	DESCRIPTION / SUPPLIER ITEM	QUANTITY	UNIT	UNIT PRICE	AMOUNT
1.0	TRANSFORMER, PAD MTD, 225 kVA	6	EA	\$25,438.0000	\$152,628.00
225 kVA, Pad Mounted Transformer					
A. SPECIFICATIONS					
A.1 Three-Phase, Dead-Front, 3 Bushing Radial Feed, Insulation Class 15 kV, BIL 95 kV, External Tap Changer, External Load Break Oil Rotary Switch (LBOR), Primary Voltage 13.8 kV, Secondary Voltage 120/208 V.					
A.2 All parts of the transformer such as hood, doors, hinges, tank, compartment, base, radiator, and other accessories shall be made of type 304L stainless steel.					
A.3 15kV, 200A load break bushing wells and inserts shall be provided, neutral grounding strap, captive pentahead bolt, LV door 3-point latching, HV door secured separately and only accessible after opening LV door, ground pads in HV and LV compartments provided with lugs/nuts for #4 to #10 copper wire.					
As per GPA Specifications No.: E-004 Revision 10 GPA Index No.: E4022513802020B-3					
B. SAFETY DATA SHEET (SDS):					
B.1 Provide consignee with 'SAFETY DATA SHEET' when making deliveries to avoid rejection.					
C. LOSS EVALUATION:					
C.1 Bid award for pad mounted transformers shall be based on the Total Cost of Ownership (TCO) and all other requirements as specified in GPA Specification E-004, Revision 10, Section 6.0.					

<b>INSTRUCTIONS TO VENDOR:</b>  SEND CERTIFIED ORIGINAL AND THREE (3) COPIES OF INVOICE TO GUAM POWER AUTHORITY, PO BOX 2977 HAGATNA, GUAM 96932  PAYMENT UPON RECEIPT OF MERCHANDISE IN GUAM IN GOOD CONDITION	<b>TOTAL</b>	<< DO NOT FILL THIS ORDER IF YOUR TOTAL COST EXCEEDS THIS TOTAL
ACKNOWLEDGED BY: <u><i>JMI Edison</i></u> DATE: <u>03/09/2026</u> SIGNATURE OF VENDOR RETURN TO PROCUREMENT DIVISION VIA FACSIMILE AT (671) 648-3165	SIGNATURE: <u><i>John M. Benavente</i></u> /11/2026 <b>JOHN M. BENAVENTE, P.E., General Manager</b> Date Delegated Authority	







