



# GUAM SOLID WASTE AUTHORITY



**LOURDES A. LEON GUERRERO**  
Governor of Guam

**JOSHUA F. TENORIO**  
Lt. Governor of Guam

**IRVIN L. SLIKE**  
General Manager

March 17, 2026

## INVITATION FOR BID GSWA-007-26 3,000-GALLON CHEMICAL STORAGE TANK

### AMENDMENT NO. 5

1. Amend page 29

From:

Deadline for Receipt of Written Questions must be emailed to the Guam Solid Waste Authority at [procurement@gswa.guam.gov](mailto:procurement@gswa.guam.gov), ATTN: General Manager

Friday, March 13, 2026  
on or before 5:00PM  
Chamorro Standard Time

Bid Due Date & Bid Opening at the Guam Solid Waste Authority:  
Superintendent's Office, GSWA Bldg., 1st Floor,  
546 N. Marine Corps Dr., Tamuning, Guam

Friday, March 20, 2026  
At 10:45 AM  
Chamorro Standard Time

To now read:

Deadline for Receipt of Written Questions must be emailed to the Guam Solid Waste Authority at [procurement@gswa.guam.gov](mailto:procurement@gswa.guam.gov), ATTN: General Manager

Friday, March 27, 2026  
on or before 5:00PM  
Chamorro Standard Time

Bid Due Date & Bid Opening at the Guam Solid Waste Authority:  
Superintendent's Office, GSWA Bldg., 1st Floor,  
546 N. Marine Corps Dr., Tamuning, Guam

Friday, April 03, 2026  
At 10:00 AM  
Chamorro Standard Time

2. Amend to replace pages 30 and 31  
**Please see attachment**

\*All others remain the same.

**Irvin L. Slike,**  
General Manager

<b>ACKNOWLEDGEMENT RECEIPT</b> Return to GSWA by email or fax.	
Received By:	_____
Date:	_____
Company Name:	_____
Fax to: 671-649-3777	
Email: <a href="mailto:procurement@gswa.guam.gov">procurement@gswa.guam.gov</a>	



# GUAM SOLID WASTE AUTHORITY

LOURDES A. LEON GUERRERO  
Governor of Guam

JOSHUA F. TENORIO  
Lt. Governor of Guam

IRVIN L. SLIKE  
General Manager



## GSWA-007-26 3,000 GALLON CHEMICAL STORAGE TANK

### BID SHEET

ITEM	DESCRIPTION	QTY	UOM	UNIT PRICE	EXTENDED PRICE
1.0	3,000 Gallon Chemical Storage Tank As per the following specifications:	1	LOT	\$	\$

#### GENERAL:

GSWA is in the market to purchase a 3,000-gallon Chemical Storage Tank for the use of our Biodiesel Fuel. The container must be able to meet the **UL 142, NFPA 30, OSHA 29 CFR 1910.106, ASCE 7** standards to hold specific chemicals/fuel. This tank will serve as the main storage for Methanol.

#### SPECIFICATIONS:

#### COMPLY / NON-COMPLIANCE

Must be in compliance with **UL 142, NFPA 30, OSHA 29 CFR 1910.106** and **ASCE 7** Structural requirements

Must be Stainless Steel or Steel Variation tank for proper long-term storage

Minimum of 102" Diameter X 150" Height

Minimum 1.5 Specific Gravity Rating (12.5 pounds per gallon)

HDPE maximum continuous use temperature of 120F

Meets ASTM D 1998-21 Wall thickness specification

Double Wall / Above Ground

Minimum of 2" PVC bulkhead fitting with Gasket

Minimum 2" PVC double flanged bolted fitting with 316 PE encapsulated bolts and gaskets

Must have Ultrasonic level indicator

Seismic restraint system required

UFO transitioning fitting

Leak detection sensor

PVC U-Vent w/ bulkhead fitting

Temperature monitor

Steel OSHA compliant ladder

Top inlet connections and vents

Bottom sidewall outlets

Flame Arrestor



# GUAM SOLID WASTE AUTHORITY

**LOURDES A. LEON GUERRERO**  
Governor of Guam

**JOSHUA F. TENORIO**  
Lt. Governor of Guam

**IRVIN L. SLIKE**  
General Manager



Pressure / Vacuum Vent

---

Emergency Vent

---

Bidder must provide shop drawings to include the following

- Tank general arrangement drawings
- Foundation / anchoring details
- Wind load design calculations
- Seismic restraint calculations
- Materials Specifications
- Nozzle and port layout
- Nameplate information

Drawings shall be reviewed & approved by GSWA prior to installation

---

Drawings shall be stamped by a professional engineer license in the United States, or otherwise acceptable for installation in Guam. GSWA will review and return the drawings "Reviewed / Approved as Notes" prior to fabrication.

---