



# GUAM SOLID WASTE AUTHORITY

LOURDES A. LEON GUERRERO  
Governor of Guam

JOSHUA F. TENORIO  
Lt. Governor of Guam

IRVIN SLIKE  
General Manager



March 17, 2026

## INVITATION FOR BID GSWA-007-26 3,000-GALLON CHEMICAL STORAGE TANK

### Questions and Concerns received from Pacific Revolution Corp on March 13, 2026

1. Come time for if the order is approved, will GSWA be able to provide a "Stamp Approved" drawing before the order can be processed?

**Answer: Yes, If the tank is awarded and prior to the fabrication, the supplier shall submit shop drawings and engineering calculations for GSWA review and approval. Please see amendment no. 5.**

2. The Certifications, according to suppliers, like those under FDA regulations would not apply as the FDA does not regulate or certify methanol storage tanks unless for use in pharmaceutical applications. Primarily OSHA and EPA would have the specific standards and certifications in regards to proper methanol storage tanks. So far, the most common Standards and Certifications I have been advised of are UL 142 and NFPA 30 as well as proper Seismic designs. Would there be any other Standards and Certifications you require of this tank?

**Please see amendment no. 5**

3. Also please advise if this would be revised in the Specifications portion of the bid.  
**Please see amendment no. 5**

4. Bid Extension  
**Please see amendment no. 5**

Irvin L. Slike,  
General Manager

### ACKNOWLEDGEMENT RECEIPT Return to GSWA by email or fax.

Received By: \_\_\_\_\_

Date: \_\_\_\_\_

Company Name: \_\_\_\_\_

Fax to: 671-649-3777

Email: [procurement@gswa.guam.gov](mailto:procurement@gswa.guam.gov)