



Mayors' Council of Guam

Kensehelon Mahet Guahan

April 9, 2026

Questions & Concerns

INVITATION FOR BID NO. MCOG-26-003

Contractual Services for the Installation of a Chain-link Perimeter Fence and Fabrication inclusive of Installation of a Double-Swing Chain-Link Gate

The following questions/concerns were received by Shinko Pacific, Inc. on April 1, 2026.

1. Question: Are there any specific requirements that indicate the length of distance between each post throughout the perimeter and how deep each post must be embedded below ground? Please provide specs, if any. Question may be relevant to question no. 2.

Response: Standard fence post for chain-link should be 8 feet-10feet. Do not exceed 10 feet. Standard for fence post should be 3 feet deep into the ground. Refer to Amendment #1.

2. Question: Although chain link measurements are indicated, will the final engineering design and layout be provided by the MCOG or be at the responsibility of the bidder upon award? Question may also be relevant to question no. 1. Per Department of Public Works, stamped engineered drawings are not needed for the 6ft perimeter fencing but are required for the 20ft high backstop.

Response: Yes, the bidder will be responsible for the final engineering design and layout to be included in bid packet submission.

3. Question: Page 4 of the IFB indicates one hundred twenty (120) days delivery date/completion, however, some pages on the IFB also indicate thirty (30) days. Please clarify turnover period. Stamped engineering designs at the responsibility of the contractor may shift the period of performance dates to the right.

Response: Due to clerical error, please refer to Amendment # 1.

4. Question: Specified materials are currently available for local procurement but may change at the time of award. Will MCOG allow contractor to utilize pipe sizes/fittings larger, but not smaller, to the specified measurements that are readily available?

Response: Yes, larger fittings are acceptable.

*** NOTHING ELSE FOLLOWS ***


JOYJEAN R. ARCEO
Executive Director

Please Print:

Acknowledgement Copy (Please email MCOG)

Received By: _____

(Print and Sign Name)

Date: _____

Company Name: _____

(Email: procurement@mcog.guam.gov)



P.O. Box 786, Hagåtña, Guam 96932
Office: (671) 472-6940 / (671) 477-8461 Fax: (671) 477-8777
E-Mail: mcogadmin@teleguam.net