



# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN  
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

May 4, 2026

**AMENDMENT NO.: I**  
**TO**  
**INVITATION FOR BID NO.: GPA-041-26**  
**FOR**  
**REPLACEMENT AND REFURBISHMENT OF 40-TON CRANE**

Prospective Bidders are hereby notified of the following responses to inquiries received from Bidder No.: 4 dated April 24, 2026:

**QUESTION:**

1. Could you please confirm whether the scope includes?

Replacement and refurbishment of crane components/parts only (i.e. repair and replacement of parts on the existing crane; or

**ANSWER:**

The main components that will be addressing are the telescopic hydraulic cylinder and the main winch, to remove and repair/rebuild the components to stop the hydraulic leaks and to be able to operate safely.

The second component to be replaced is the main controller. The component is located inside the operator cab which the operator selects the functions. This will need to be program/flash to the crane.

**QUESTION:**

2. Could you please confirm whether the scope includes?

Replacement of the existing crane with a new crane, in addition to refurbishment or replacement of components as required.

**ANSWER:**

This tender requires to upgrade and repair the Groove crane not for replacement.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
JOHN M. BENAVENTE, P.E.  
General Manager 