



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

May 15, 2026

AMENDMENT NO.: I

TO

INVITATION FOR BID NO.: GPA-048-26

FOR

BRACKET, STREETLIGHT, MAST ARM

Prospective Bidders are hereby notified of the following response to an inquiry received from Bidder No.: 4 dated May 13, 2026:

QUESTION:

1. I have a supplier asking if there is an absolute need for the mast arms to be aluminium. The specs call for iron or steel, but as we know, iron/steel rusts where aluminum does not. Kindly advise it's more of a tensile issue.

ANSWER:

Refer to GPA Specification E-005, Revision 4, Section 5.8.4, "The mast arm shall be made of three 6063-T6 aluminum alloy extrusion".

All other Terms and Conditions in the bid package shall remain unchanged and in full force.


JOHN M. BENAVENTE, P.E.
 General Manager