



# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN  
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

May 15, 2026

## AMENDMENT NO.: II

TO

## INVITATION FOR MULTI-STEP GPA-043-26

FOR

### PETROLEUM INSPECTION AND TESTING SERVICES FOR DIESEL FUEL OIL NO. 2

Prospective Bidders are hereby notified of the following responses to inquiries received from Bidder No.1 dated April 30, 2026:

#### **RESPONSE:**

#### **Bidder No.: 1 dated 04/30/2026**

#### **QUESTION:**

##### **A. Section 4.5.2 – Delivery Timeline of Test Results**

1. Considering that certain test parameters may require subcontracting to off-island laboratories, will GPA allow exception or extension to the four (4) working day requirement for submission of complete test results?

#### **ANSWER:**

GPA will not allow an extension to the four (4) working day requirement for submission of complete test results.

The four (4) working day requirement is deemed sufficient for both shipment of samples and completion of off-island laboratory testing. Based on standard logistics timelines, shipment from Guam to Singapore typically requires only approximately two (2) to three (3) days transit time. In addition, the off-island laboratory testing can reasonably be completed within the remaining timeframe.

Accordingly, GPA expects that complete and final test results shall be submitted within four (4) working days from the date of tank sampling, inclusive of any off-island testing requirements.

#### **QUESTION:**

2. Will partial test results be acceptable within the required four (4) working day period, with the final results to follow once subcontracted analyses are completed?

#### **ANSWER:**

GPA will accept partial test results, pending only the off-island parameters test results, but must be finalized and completed within the four (4) day timeline.


#### **QUESTION:**

Does the four (4) working day requirement apply to all parameters, including those performed off-island?

**ANSWER:**

The four (4) day timeline applies only for the off-island testing parameters, On-island testing parameters needs be completed within twenty-four (24) hours upon commencement of testing (usual testing time).

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
JOHN M. BENAVENTE,  
P.E. General Manager