



# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN  
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

June 12, 2026

**AMENDMENT NO.: I**

**TO**

**INVITATION FOR BID NO.: GPA-054-26**

**FOR**

**POLE MOUNTED TRANSFORMERS**

Prospective Bidders are hereby notified of the following response to an inquiry received from Bidder No.: 11 dated June 11 2026:

**RESPONSE:**

**QUESTION:**


1. We would like to clarify the following:

Item A.2 (page 4, 6, 8, 10, and 12) – It says “The Tank, tank cover, **mounting bracket** and cover band shall be made of Type 304L stainless steel”. Kindly let us know what mounting bracket GPA is referring to.

**ANSWER:**

The mounting brackets referred to include all brackets, such as lightning arrester brackets and hanger brackets.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
JOHN M. BENAVENTE, P.E.  
General Manager 