



GUAM POWER AUTHORITY

ATURIDÂT ILEKTRESEDÂT GUAHAN
P.O.BOX 2977 • HAGÂTNÂ, GUAM U.S.A. 96932-2977

July 08, 2026

AMENDMENT NO.: II
TO
INVITATION FOR BID NO.: GPA-065-26
FOR
Wire(s)

Prospective Bidders are hereby notified of the following response to inquiry received from Bidder No. 9 dated June 27, 2026:

RESPONSE:

Bidder No.: 9 dated 06/27/2026:

QUESTION:

1. In GPA Specification E-022, Revision3 Table A includes more than one #2 AWG Triplex configuration depending on the neutral-messenger size.

Could you please confirm which configuration corresponds to GPA Index No. SSOW1425?

Specifically, please confirm whether SSOW1425 requires:

#2 AWG phase conductor with #4 AWG neutral-messenger, or
#2 AWG phase conductor with #2 AWG neutral-messenger.

ANSWER:

#2 AWG phase conductor with #2 AWG neutral-messenger.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

JOHN M. BENAVENTE, P.E.
General Manager